

**APPENDIX B**  
**OREGON WATER WELL DRILLERS LOGS**

Well Log Report

Township: 18S, Range: 4W, Section: 10,11,14,15

Well Log	First Water (ft. bgs)	Completed Depth (ft. bgs)	Static Water (ft. bgs)	Yield (gpm)
LANE 1385	30	90	1	150
LANE 1386	62	200	41	20
LANE 1387	80	240	55	25
LANE 1388	90	110	32	15
LANE 1389	80	180	10	14
LANE 1390	31	400	15	1
LANE 1391	125	200	12	15
LANE 16780	142	190	42	9
LANE 16990		215	40	40
LANE 16991	85	90	30	25
LANE 16992	70	100	30	10
LANE 16993	190	192	140	60
LANE 16994	125			
LANE 16995	52	97	30	30
LANE 16997		132	75	0.8
LANE 16999		140	62	25
LANE 17000	78	105	46	20
LANE 17001	240	250	50	20
LANE 17002	83	294	56	15
LANE 17003	110	112	95	15
LANE 17004	44	95	15	9
LANE 17005	32	255	18	12
LANE 17006	92	100	20	11
LANE 17007		210	42	9
LANE 17021	70	160	20	20
LANE 17022	129	275	51	2
LANE 17023	350	385	100	7.5
LANE 17024		84	22	7.5
LANE 17025	215	290	30	15
LANE 17026	130	360	28	2
LANE 17027	40	105	25	1.5
LANE 17028	60			
LANE 17029	45	400	50	7.5
LANE 17030	30	205	5	2
LANE 17031	72	127	13	8
LANE 17032		120	7.5	8
LANE 17033		155	60	10
LANE 17034		230	80	9
LANE 17035	78	155	24	18
LANE 17036	185	425	90	1.5
LANE 17037	210	270	210	
LANE 17039	75	100	21	15
LANE 17040		150	30	1
LANE 17041		97	25	30
LANE 17042		230		1
LANE 17043		222	40	3
LANE 17044	104	150	48	7.5
LANE 17045	191	201	41	16
LANE 17046	60	88	18	35
LANE 17047	55	67	17	40
LANE 17048	90	340	15	2

Well Log	First Water (ft. bgs)	Completed Depth (ft. bgs)	Static Water (ft. bgs)	Yield (gpm)
LANE 17049		300	17	4
LANE 17050		50		
LANE 17051		105	24	1.7
LANE 17052		502	180	20
LANE 17053		120	65	8
LANE 17054	130	240	2	60
LANE 17055	148	228	48	10.5
LANE 17056	80	175	15	12
LANE 17057				
LANE 17058				
LANE 17059	125	137	28	5.8
LANE 17060		360	70	8
LANE 17061		131	54	1
LANE 17062		200	55	180
LANE 17063		310	150	60
LANE 17064		145	20	10
LANE 17065		65	23	60
LANE 17066	140	240	40	2
LANE 17067	65	80	35	17
LANE 17068		171	55	50
LANE 2829	138	145	59	20
LANE 2927	90	160	45	12
LANE 3330	28	50	9	10
LANE 4056	44	110	16	12.5
LANE 4472	73	120	15	100
LANE 4704	470	550	190	15
LANE 4818	81	330	24	4
LANE 50024	185	450	177	50
LANE 50594	58	380	58	2.5
LANE 50595	68	160	14	13
LANE 50600	113	220	75	21
LANE 51061	74	170	28	5
LANE 52540		200	6	2
LANE 52541	218	235	62	14.5
LANE 52916	65	145	60	10
LANE 52917	280	360	60	8
LANE 58511				
LANE 58653				
LANE 58950	566	600	165	12
LANE 59411	180	330	97	11
LANE 59895	87	110	20	8
LANE 89	75	173	18	50

Count	64	87	85	85
Min	28	50	1	0.8
Max	566	600	210	180
Mean	119	206	48	20
Median	84	175	35	12
Mode	80	200	15	15

WATER WELL REPORT  
STATE OF OREGON

**RECEIVED**

SEP 18 1981

WATER RESOURCES DEPT

State Well No. 18S/HW-10

State Permit No. \_\_\_\_\_

*Handwritten notes and stamps:*  
1385  
1385

(1) OWNER: SALEM, OREGON  
Name Ken Kumbler  
Address 3499 W 15<sup>th</sup>  
City Elaine State OR

(10) LOCATION OF WELL:  
County LANE Driller's well number \_\_\_\_\_  
1/4 Section 10 T. 18S R. 4W W.M.  
Tax Lot # 500 Lot Blk Subdivision \_\_\_\_\_  
Address at well location: \_\_\_\_\_

(2) TYPE OF WORK (check):  
New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 12.

(11) WATER LEVEL: Completed well  
Depth at which water was first found 30  
Static level +1 ft. below land surface. Date 9-17-81  
Artesian pressure \_\_\_\_\_ lbs. per square-inch. Date \_\_\_\_\_

(3) TYPE OF WELL: (4) PROPOSED USE (check):  
Rotary Air  Driven  Domestic  Industrial  Municipal   
Rotary Mud  Dog  Irrigation  Test Well  Other   
 Bored  Thermal  Withdrawal  Reinjection

(5) CASING INSTALLED: Steel  Plastic   
Threaded  Welded   
6" Diam. from 24 ft. to 24 ft. Gauge 150  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gauge \_\_\_\_\_

(12) WELL LOG: Diameter of well below casing 6  
Depth drilled 90 ft. Depth of completed well 90 ft.  
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

(6) LINER INSTALLED: # 160  
" Diam. from 70 ft. to 90 ft. Gauge \_\_\_\_\_

MATERIAL	From	To	SWL
soil clay	0	13	
red rock	13	23	
Blue Rock	23	27	
red rock	27	37	
Blue Rock w/B	37	60	
light grey	60	70 + 1'	
light grey w/B	70	81	
light grey	81	90 + 1'	

(6) PERFORATIONS: Perforated?  Yes  No  
Type of perforator used rod drill  
Size of perforations 7/8 in. by \_\_\_\_\_ in.  
\_\_\_\_\_ perforations from 70 ft. to 90 ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(7) SCREENS: Well screen installed?  Yes  No  
Manufacturer's Name \_\_\_\_\_  
Type \_\_\_\_\_ Model No. \_\_\_\_\_  
Diam. \_\_\_\_\_ Slot Size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Diam. \_\_\_\_\_ Slot Size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level.  
Was a pump test made?  Yes  No If yes, by whom?  
\_\_\_\_\_ gal/min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
Air test 150 + gal/min. with drill stem at 90 ft. \_\_\_\_\_ hrs.  
Ball test \_\_\_\_\_ gal/min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
Artesian flow \_\_\_\_\_ g.p.m.  
Temperature of water \_\_\_\_\_ Depth artesian flow encountered 80 ft.

Work started 9-13 1981 Completed 9-13 1981  
Date well drilling machine moved off of well 9-13 1981

(9) CONSTRUCTION: Special standards: Yes  No   
Well seal—Material used Cement grout  
Well sealed from land surface to \_\_\_\_\_ ft.  
Diameter of well bore to bottom of seal 6 in.  
Diameter of well bore below seal \_\_\_\_\_ in.  
Number of sacks of cement used in well seal 3 sacks  
How was cement grout placed? Pumped

Drilling Machine Operator's Certification:  
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.  
[Signed] Carl P. [Signature] Date 9-13, 1981  
Drilling Machine Operator's License No. 3BC

Was pump installed? \_\_\_\_\_ Type \_\_\_\_\_ HP \_\_\_\_\_ Depth \_\_\_\_\_ ft.  
Was a drive shoe used?  Yes  No Plug \_\_\_\_\_ Size: location \_\_\_\_\_ ft.  
Did any strata contain unusable water?  Yes  No  
Type of Water? \_\_\_\_\_ depth of strata \_\_\_\_\_  
Method of sealing strata off \_\_\_\_\_  
Was well gravel packed?  Yes  No Size of gravel: \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

Water Well Contractor's Certification:  
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  
Name Fitch & Dunning  
Address 1825 W. [Address]  
[Signed] Carl P. [Signature]  
Contractor's License No. 494 Date 9-13, 1981

NOTICE TO WATER WELL CONTRACTOR  
The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT,  
SALEM, OREGON 97310  
within 30 days from the date of well completion.

SP-12658-090

NOTICE TO WATER WELL CONTRACTOR  
The original and first copy of this report  
are to be filed with the  
WATER RESOURCES DEPARTMENT,  
SALEM, OREGON 97310  
within 30 days from the date  
of well completion.

WATER WELL REPORT  
STATE OF OREGON  
(Please type or print)  
AUG 7 1978  
Do not write above this line

PUMP  
1230

State Well No. 185/4W-10  
State Permit No.

(1) OWNER: Name Mr. Jerry Gilbert  
Address 3175 Bailey Hill Road, Eugene, Oregon

(10) LOCATION OF WELL: County Lane Driller's well number  
Section 10 T. 18S R. 4W W.M.  
Bearing and distance from section or subdivision corner

(2) TYPE OF WORK (check):  
New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 12

(3) TYPE OF WELL: Rotary  Driven   
Cable  Jetted   
Dug  Bored   
(4) PROPOSED USE (check): Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

CASING INSTALLED: Threaded  Welded   
Diam. from +1 ft. to 39 ft. Gage .250  
Diam. from ft. to ft. Gage  
Diam. from ft. to ft. Gage

PERFORATIONS: Perforated?  Yes  No.  
Type of perforator used  
Size of perforations in. by in.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.

(7) SCREENS: Well screen installed?  Yes  No  
Manufacturer's Name  
Type Model No.  
Diam. Slot size Set from ft. to ft.  
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level  
Was a pump test made?  Yes  No If yes, by whom?  
Yield: 20 gal./min. with 159 ft. drawdown after 2 hrs.  
Air Rotary Developed  
Ballor test gal./min. with ft. drawdown after hrs.  
Artesian flow g.p.m.  
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION: Well seal—Material used Portland Cement  
Well sealed from land surface to 39 ft.  
Diameter of well bore to bottom of seal 10 in.  
Diameter of well bore below seal 6 in.  
Number of sacks of cement used in well seal 11 sacks  
How was cement grout placed? Mixed and poured from the top.

Was a drive shoe used?  Yes  No Plug Size: location ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? depth of strata  
Method of sealing strata off  
Was well gravel packed?  Yes  No Size of gravel:  
Gravel placed from ft. to ft.

(11) WATER LEVEL: Completed well.  
Depth at which water was first found 62 ft.  
Static level 41 ft. below land surface. Date 7/11/78  
Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing 6  
Depth drilled 200 ft. Depth of completed well 200 ft.  
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	BWL
Topsoil	0	3	
Brown clay	3	19	
Weathered sandstone	19	25	
Gray sandstone	25	200	41'

Work started 7/7 1978 Completed 7/11 1978  
Date well drilling machine moved off of well 7/11 1978

Drilling Machine Operator's Certification:  
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.  
[Signed] Ronald J. Fox Date 7/13 1978  
Drilling Machine Operator's License No. 1043

Water Well Contractor's Certification:  
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  
Name Pitcher Pump & Drilling Company  
Address 150 RIVER AVE., Eugene, Or 97404  
[Signed] Carl Pitcher  
Contractor's License No. 494 Date 7/13 1978

NOTICE TO WATER WELL CONTRACTOR  
 The original and first copy  
 of this report are to be  
 filed with the  
 STATE ENGINEER, SALEM, OREGON  
 within 30 days from the date  
 of well completion.

RECEIVED  
 APR 29 1974  
 STATE ENGINEER  
 SALEM, OREGON

State Well No. 185/4W-11  
 State Permit No. \_\_\_\_\_

(1) OWNER:  
 Name Dr. Don Fox  
 Address 3790 Onyx St.  
Eugene, Oregon

(2) TYPE OF WORK (check):  
 New Well  Deepening  Reconditioning  Abandon   
 If abandonment, describe material and procedure in Item 13.

(3) TYPE OF WELL: (4) PROPOSED USE (check):  
 Rotary  Driven  Domestic  Industrial  Municipal   
 Cable  Jetted  Irrigation  Test Well  Other   
 Dug  Bored

(5) CASING INSTALLED: Threaded  Welded   
 6" Diam. from 0 ft. to 32 ft. Gage 250  
 " Diam. from " ft. to " ft. Gage  
 " Diam. from " ft. to " ft. Gage

(6) PERFORATIONS: Perforated?  Yes  No.  
 Type of perforator used \_\_\_\_\_  
 Size of perforations in. by in.  
 perforations from ft. to ft.  
 perforations from ft. to ft.  
 perforations from ft. to ft.

(7) SCREENS: Well screen installed?  Yes  No  
 Manufacturer's Name \_\_\_\_\_  
 Type \_\_\_\_\_ Model No. \_\_\_\_\_  
 Diam. Slot size Set from ft. to ft.  
 Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level.  
 Was a pump test made?  Yes  No. If yes, by whom?  
 Yield: gal./min. with ft. drawdown after hrs.  
 Ratter test 25 gal./min. with 45 ft. drawdown after 1 hrs.  
 Artesian flow \_\_\_\_\_  
 Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:  
 Well seal—Material used Cement  
 Well sealed from land surface to 0 to 32 ft.  
 Diameter of well bore to bottom of seal 10 in.  
 Diameter of well bore below seal 6 in.  
 Number of sacks of cement used in well seal 8 sacks  
 Number of sacks of bentonite used in well seal \_\_\_\_\_ sacks  
 Brand name of bentonite \_\_\_\_\_  
 Number of pounds of bentonite per 100 gallons of water \_\_\_\_\_ lbs./100 gals.  
 Was a drive shoe used?  Yes  No. Plug \_\_\_\_\_ Size: location \_\_\_\_\_ ft.  
 Did any strata contain unusable water?  Yes  No  
 Type of water \_\_\_\_\_ depth of strata \_\_\_\_\_  
 Method of sealing strata off \_\_\_\_\_  
 Was well gravel packed?  Yes  No. Size of gravel: \_\_\_\_\_  
 Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(10) LOCATION OF WELL:  
 County \_\_\_\_\_ Lane \_\_\_\_\_ Driller's well number 776-71  
 NW 1/4 Section 11 T. 18 R. 11W W.M.  
 Bearing and distance from section or subdivision corner \_\_\_\_\_

(11) WATER LEVEL: Completed well.  
 Depth at which water was first found 80 ft.  
 Static level 55 ft. below land surface. Rate 3-29-74  
 Artesian pressure \_\_\_\_\_ lbs. per square inch. Date \_\_\_\_\_

(12) WELL LOG: Diameter of well below casing 6"  
 Depth drilled 240 ft. Depth of completed well 240 ft.  
 Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Brown Top Soil	0	1	
Yellow Clay	1	20	
Dark Blue Shale	20	65	
Blue Shale	65	100	55
Dark Brown Shale	100	155	
Blue & Red Mixed Shale	155	190	
Red Shale	190	205	
Blue Shale	205	240	55

Work started 3-25 1974 Completed 4-1 1974  
 Date well drilling machine moved off of well 4-1 1974

Drilling Machine Operator's Certification:  
 This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.  
 [Signed] Clifford Cronin Date 4-1 1974  
 (Drilling Machine Operator)  
 Drilling Machine Operator's License No. 148

Water Well Contractor's Certification:  
 This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  
 Name CARTER DRILLING & PUMP SERVICE  
 (Contractor, firm or corporation)  
 Address P.O. BOX 46, SPRINGFIELD, OREGON 97177  
 [Signed] \_\_\_\_\_  
 (Water Well Contractor)  
 Contractor's License No. 126 Date April 11, 1974

NOV 9 1987

1388

18-4W-K

STATE OF OREGON WATER WELL REPORT (as required by ORS 837.765)

WATER RESOURCES DEPT. SALEM, OREGON

(1) OWNER: Name Evelyn Hile, Address 2887 Harlow Rd., City Eugene, State Or., Zip 97401

(2) TYPE OF WORK: [X] New Well, [ ] Deepen, [ ] Recondition, [ ] Abandon

(3) DRILL METHOD: [X] Rotary Air, [ ] Rotary Mud, [ ] Cable, [ ] Other

(4) PROPOSED USE: [X] Domestic, [ ] Community, [ ] Industrial, [ ] Irrigation, [ ] Thermal, [ ] Injection, [ ] Other

(5) BORE HOLE CONSTRUCTION: Special Construction approval Yes No, Depth of Completed Well 110 ft., Explosives used [ ] [X] Type Amount

Table with columns: HOLE Diameter From To, SEAL Material From To, Amount sacks or pounds. Row 1: 10", 0, 77, Cement, 0, 77, 30 sacks. Row 2: 6", 77, 110

How was seal placed: Method [ ] A [ ] B [X] C [ ] D [ ] E, Backfill placed from ft. to ft. Material, Gravel placed from ft. to ft. Size of gravel

(6) CASING/LINER: Table with columns: Diameter, From, To, Gauge, Steel, Plastic, Welded, Threaded. Casing: 6", +1, 79, .250, [X], [ ], [X], [ ]. Liner: [ ], [ ], [ ], [ ], [ ], [ ], [ ], [ ]

(7) PERFORATIONS/SCREENS: [ ] Perforations Method, [ ] Screens Type Material

Table with columns: From, To, Slot size, Number, Diameter, Tele/pipe size, Casing, Liner

(8) WELL TESTS: Minimum testing time is 1 hour. [ ] Pump, [ ] Baller, [X] Air, [ ] Flowing Artesian. Yield gal/min 15, Drawdown 77, Drill stem at 110, Time 1 hr.

Temperature of water, Depth Artesian Flow Found, Was a water analysis done? [ ] Yes By whom, Did any strata contain water not suitable for intended use? [ ] Too little, [ ] Salty, [ ] Muddy, [ ] Odor, [ ] Colored, [ ] Other not tested

(9) LOCATION OF WELL by legal description: County Lane, Latitude, Longitude, Township 18S, N or S. Range 4W, E or W, WM, Section 14, Tax Lot 700, Lot, Block, Subdivision, Street Address of Well (or nearest address) next to 86448, Lorane Hwy., Eugene, Or., 97405

(10) STATIC WATER LEVEL: 32 ft. below land surface, Date 10-16-87, Artesian pressure lb. per square inch, Date

(11) WATER BEARING ZONES: Table with columns: From, To, Estimated Flow Rate, SWL. Row 1: 90, 91', 15, 32'

(12) WELL LOG: Table with columns: Material, From, To, SWL. Rows: Topsoil (0-1), Brown Clay (1-19), Boulders (19-20), Brown Clay (20-31), Gray Brown Claystone (31-40), Gray Brown Fractured Claystone (40-72), Blue Soft Sandstone (72-110), 32'

(unbonded) Water Well Constructor Certification: I certify that the work I performed on the construction, alteration, or abandonment of this well is in compliance with Oregon well construction standards. Signed Bob Murphy, WWC Number 1344, Date 10-16-87

(bonded) Water Well Constructor Certification: I accept responsibility for the construction, alteration, or abandonment work performed on this well during the construction dates reported above. Signed Casey Jones, WWC Number 559, Date 10-16-87

NOTICE TO WATER WELL CONTRACTOR  
The original and first copy of this report  
are to be filed with the

WATER RESOURCES DEPARTMENT,  
SALEM, OREGON 97310  
within 30 days from the date  
of well completion.

**WATER WELL REPORT**

STATE OF OREGON  
(Please type or print)

(Do not write above this line)

*1288*  
*1981*

State Well No. 1854w-14b

State Permit No. \_\_\_\_\_

**(1) OWNER:**

Name Jerry Strand  
Address 86501 Loraine Hwy.  
Eugene, Oregon

**(2) TYPE OF WORK (check):**

New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in item 12.

**(3) TYPE OF WELL:**

Cased  Driven   
 Cable  Jetted   
 Dug  Bored

**(4) PROPOSED USE (check):**

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

**(5) CASING INSTALLED:**

Threaded  Welded   
6" Diam. from +1 ft. to 39 ft. Gage .250  
5" Diam. from 30 ft. to 180 ft. Gage .188  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_

**(6) PERFORATIONS:**

Perforated?  Yes  No  
Type of perforator used Torch (Steel Liner Only)  
Size of perforations 1/4 in. by 3/4 in.  
33 perforations from 80 ft. to 100 ft.  
33 perforations from 110 ft. to 160 ft.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

**(7) SCREENS:**

Wall screen installed?  Yes  No  
Manufacturer's Name \_\_\_\_\_  
Type \_\_\_\_\_ Model No. \_\_\_\_\_  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

**(8) WELL TESTS:**

Drawdown is amount water level is lowered below static level  
Air  
Was a pump test made?  Yes  No If yes, by whom? Driller  
Yield: 1 1/4 gal./min. with 160 ft. drawdown after 1 hrs.  
Water test NO gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
Artesian flow NO  
Temperature of water 58 Depth artesian flow encountered \_\_\_\_\_ ft.

**(9) CONSTRUCTION:**

Well seal—Material used Portland Cement Type III  
Well sealed from land surface to 22 ft.  
Diameter of well bore to bottom of seal 10 in.  
Diameter of well bore below seal 8 3/4-6 in.  
Number of sacks of cement used in well seal 6 sacks  
How was cement grout placed? Method "C"  
Was a drive shoe used?  Yes  No Plug \_\_\_\_\_ Size: location \_\_\_\_\_ ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? \_\_\_\_\_ depth of strata \_\_\_\_\_  
Method of sealing strata off \_\_\_\_\_  
Was well gravel packed?  Yes  No Size of gravel: \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

**(10) LOCATION OF WELL:**

County Lane Driller's well number 2191/670  
1/4 NW 1/4 Section 11 T. 18 R. 1W W.M.  
Bearing and distance from section or subdivision corner \_\_\_\_\_

**(11) WATER LEVEL: Completed well.**

Depth at which water was first found 80 ft.  
Static level 10 ft. below land surface. Date 9/21/79  
Artesian pressure \_\_\_\_\_ lbs. per square inch. Date \_\_\_\_\_

**(12) WELL LOG:**

Diameter of well below casing 6"  
Depth drilled 180 ft. Depth of completed well 180 ft.  
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Top Soil	0	2	
Brown Clay	2	6	
Blue Clay	6	13	
Soft Blue Shale	13	115	10
Hard Grey Basalt	115	115	10
Soft Blue Shale	115	180	10

RECEIVED

OCT - 3 1979

WATER RESOURCES DEPT

Work started 9/21/79 Completed 9/24/79  
Date well drilling machine moved off of well 9/25/79

Drilling Machine Operator's Certification:  
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.  
[Signed] \_\_\_\_\_ Date \_\_\_\_\_ 19\_\_  
(Drilling Machine Operator)  
Drilling Machine Operator's License No. 717

Water Well Contractor's Certification:  
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  
Name Carter's Drilling & Pump Service  
Address P.O. Box 16 Springfield, Oregon 97177  
[Signed] \_\_\_\_\_ Date 9/25/79 19\_\_  
(Water Well Contractor)  
Contractor's License No. 126

(USE ADDITIONAL SHEETS)



NOTICE TO WATER WELL CONTRACTOR  
The original and first copy  
of this report are to be  
filed with the  
STATE ENGINEER, SALEM, OREGON 97310  
within 30 days from the date  
of well completion.

WATER WELL REPORT

STATE OF OREGON  
(Please type or print)

RECEIVED

Well No. 185/4W-14

FEB 8 1977 State Permit No.

(1) OWNER:

Name LARRY DOURVOY  
Address 82319 LORANE HIGHWAY  
EUGENE

(2) TYPE OF WORK (check):

New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in item 12.

(3) TYPE OF WELL:

Rotary  Driven   
Cable  Jetted   
Dug  Bored

(4) PROPOSED USE (check):

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

(5) CASING INSTALLED:

Threaded  Welded   
6" Diam. from 41 ft. to 273 ft. Gage 1/4  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_

(6) PERFORATIONS:

Perforated?  Yes  No  
Type of perforator used \_\_\_\_\_  
Size of perforations \_\_\_\_\_ in. by \_\_\_\_\_ in.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(7) SCREENS:

Well screen installed?  Yes  No  
Manufacturer's Name \_\_\_\_\_  
Type \_\_\_\_\_ Model No. \_\_\_\_\_  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level  
Was a pump test made?  Yes  No If yes, by whom?  
d: \_\_\_\_\_ gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
WELL OUTPUT MAY FLUCTUATE  
Pump test 1 gal./min. with MAX ft. drawdown after 8 hrs.  
Artesian flow \_\_\_\_\_ g.p.m.  
Temperature of water \_\_\_\_\_ Depth artesian flow encountered \_\_\_\_\_ ft.

(9) CONSTRUCTION:

Well seal—Material used CEMENT GROUT  
Well sealed from land surface to 27 ft.  
Diameter of well bore to bottom of seal 10 in.  
Diameter of well bore below seal 6 in.  
Number of sacks of cement used in well seal 6 sacks  
Number of sacks of bentonite used in well seal \_\_\_\_\_ sacks  
Brand name of bentonite \_\_\_\_\_  
Number of pounds of bentonite per 100 gallons of water \_\_\_\_\_ lbs./100 gals.  
Was a drive shoe used?  Yes  No Plugs \_\_\_\_\_ Size: location \_\_\_\_\_ ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? \_\_\_\_\_ depth of strata \_\_\_\_\_  
Method of sealing strata off \_\_\_\_\_  
Was well gravel packed?  Yes  No Size of gravel: \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

WATER RESOURCES DEPT.

(10) LOCATION ORIGIN:

County LANE Driller's well number 7672  
1/4 Section 14 T. 18S R. 4W W.M.  
Bearing and distance from section or subdivision corner \_\_\_\_\_

(11) WATER LEVEL: Completed well.

Depth at which water was first found 31 ft.  
Static level 15 ft. below land surface. Date 9-22-76  
Artesian pressure \_\_\_\_\_ lbs. per square inch. Date \_\_\_\_\_

(12) WELL LOG:

Diameter of well below casing 6  
Depth drilled 400 ft. Depth of completed well 400 ft.  
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
BASALT	0	135	
TUFFACEOUS SS	135	344	
BASALT	344	364	
TUFFACEOUS SS	364	400	

Work started 9-20 1976 Completed 9-22 1976

Date well drilling machine moved off of well 9-22 1976

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Seal Christensen Date 9/23, 1976  
(Drilling Machine Operator)

Drilling Machine Operator's License No. 612

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name MARK CHRISTENSEN  
(Person, firm or corporation) (Type or print)

Address 33132 COLEMAN RD EUGENE

[Signed] Mark Christensen  
(Water Well Contractor)

Contractor's License No. 97 Date 9-23, 1976

(USE ADDITIONAL SHEETS IF NECESSARY)

SP-45436-119

NOTICE TO WATER WELL CONTRACTOR  
The original and first copy of this report  
are to be filed with the  
WATER RESOURCES DEPARTMENT,  
SALEM, OREGON 97310  
within 30 days from the date  
of well completion.

**WATER WELL REPORT**  
STATE OF OREGON  
(Please type or print)  
(Do not write above this line)

1391

State Well No. 180/4w-15  
State Permit No. \_\_\_\_\_

(1) OWNER:  
Name Mr. Robert G. Smith  
Address 86182 Lorane Hwy  
Eugene, OR 97405

(2) TYPE OF WORK (check):  
New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL: (4) PROPOSED USE (check):  
Rotary  Driven  Domestic  Industrial  Municipal   
Cable  Jetted  Irrigation  Test Well  Other   
Dug  Bored

CASING INSTALLED: Threaded  Welded   
6" Id Diarn. from Plus 1 ft. to 24 ft. Gage 250  
" Diarn. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_  
" Diarn. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_

PERFORATIONS: Perforated?  Yes  No.  
Type of perforator used \_\_\_\_\_  
Size of perforations in. by \_\_\_\_\_ in.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(7) SCREENS: Well screen installed?  Yes  No  
Manufacturer's Name \_\_\_\_\_  
Type \_\_\_\_\_ Model No. \_\_\_\_\_  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level  
Was a pump test made?  Yes  No If yes, by whom?  
Yield: \_\_\_\_\_ gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
Well output may fluctuate  
At: \_\_\_\_\_  
Water test 15 gal./min. with MAX ft. drawdown after 1 hr.  
Artesian flow \_\_\_\_\_ g.p.m.  
Temperature of water \_\_\_\_\_ Depth artesian flow encountered \_\_\_\_\_ ft.

(9) CONSTRUCTION:  
Well seal—Material used Cement grout  
Well sealed from land surface to 24 ft.  
Diameter of well bore to bottom of seal 10 in.  
Diameter of well bore below seal 6 in.  
Number of sacks of cement used in well seal 9 sacks  
How was cement grout placed?  
Machine mixed - pumped to dry seal area

Was a drive shoe used?  Yes  No Plugs \_\_\_\_\_ Size: location \_\_\_\_\_ ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? \_\_\_\_\_ depth of strata \_\_\_\_\_  
Method of sealing strata off \_\_\_\_\_  
Was well gravel packed?  Yes  No Size of gravel: \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(10) LOCATION OF WELL:  
County Lane \_\_\_\_\_ Driller's well number 7950  
1/4 1/4 Section 15 T. 18s R. 4w W.M.  
Bearing and distance from section or subdivision corner \_\_\_\_\_

(11) WATER LEVEL: Completed well.  
Depth at which water was first found 125 ft.  
Static level 12 ft. below land surface. Date 6-15-79  
Artesian pressure \_\_\_\_\_ lbs. per square inch. Date \_\_\_\_\_

(12) WELL LOG: Diameter of well below casing 6"  
Depth drilled 200 ft. Depth of completed well 200 ft.  
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Clay - Brown Boulders/small	0	12	
B/G Med. Hard Sandstone	12	27	
Basalt - Blue/hard	27	42	
B/G Med. Hard Sandstone	42	200	

RECEIVED

JUN 26 1979

WATER RESOURCES DEPT  
SALEM, OREGON

Work started 6-14-79 19 Completed 6-15-79 19  
Date well drilling machine moved off of well 6-15-79 19

Drilling Machine Operator's Certification:  
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.  
[Signed] Ray W. [Signature] Date 6-15-79 19  
(Drilling Machine Operator)  
Drilling Machine Operator's License No. 1234

Water Well Contractor's Certification:  
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  
Name Mark Christensen  
(Person, firm or corporation) (Type or print)  
Address 33132 Coleman Road, Eugene, OR 97401  
[Signed] Mark Christensen  
(Water Well Contractor)  
Contractor's License No. 97 Date 6-15-79 19

RECEIVED LANE

JAN 26 1989

(START CARD) # 9505

STATE OF OREGON WATER WELL REPORT (as required by ORS 637.788)

(1) OWNER: Evelyn Hile, 2887 Harlow Rd., Eugene, Or. 97401

(2) TYPE OF WORK: New Wall

(3) DRILL METHOD: Rotary Air

(4) PROPOSED USE: Domestic

(5) BORE HOLE CONSTRUCTION: Special Construction approval Yes No, Depth of Completed Well 190 ft.

Table with columns: HOLE Diameter, SEAL Material, Amount sacks or pounds

How was seal placed: Method A B C D E, Backfill placed from, Gravel placed from

(6) CASING/LINER: Table with columns: Diameter, From, To, Gauge, Steel, Plastic, Welded, Threaded

(7) PERFORATIONS/SCREENS: Perforations Method SAV, Screens Type Material

Table with columns: From, To, Slot size, Number, Diameter, Telepipe size, Casing, Liner

(8) WELL TESTS: Minimum testing time is 1 hour, Pump, Bailer, Air, Artesian, Yield gal/min, Drawdown, Drill stem at, Time

Temperature of water, Depth Artesian Flow Found, Was a water analysis done?, Did any strata contain water not suitable for intended use?, Depth of strata

(9) LOCATION OF WELL by legal description: County Lane, Township 18S, Section 14, Tax Lot 700, Street Address of Well Lorane Hwy. Eugene, Or.

(10) STATIC WATER LEVEL: 42' ft. below land surface, Date 1-18-89

(11) WATER BEARING ZONES: Table with columns: From, To, Estimated Flow Rate, SWL

(12) WELL LOG: Table with columns: Material, From, To, SWL

Date started 1-16-89, Completed 1-18-89

(unbonded) Water Well Constructor Certification: I certify that the work I performed on the construction, alteration, or abandonment of this well is in compliance with Oregon well construction standards.

(bonded) Water Well Constructor Certification: I accept responsibility for the construction, alteration, or abandonment work performed on this well during the construction dates reported above.



RECEIVED

JUN 11 1984 State Well No. 185/4W-1066

WATER RESOURCES DEPT. PERMIT NO. LANE 16791

PLEASE TYPE OR PRINT SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON

(1) OWNER:

Name STEVEN BENNETT
Address 1590 HIGH ST.
City ELLENE State ORE

(2) TYPE OF WORK (check):

New Well [X] Deepening [ ] Reconditioning [ ] Abandon [ ]

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Air [X] Driven [ ]
Domestic [X] Industrial [ ] Municipal [ ]
Irrigation [ ] That Well [ ] Other [ ]
Bored [ ] Thermal [ ] Withdrawal [ ] Rejection [ ]

(4) PROPOSED USE (check):

(5) CASING INSTALLED: Steel [X] Plastic [ ]
Threaded [ ] Welded [ ]
6" Diam. from 7.1 ft. to 12 ft. Gauge 2.50

LINER INSTALLED:

(6) PERFORATIONS:

Perforated? [ ] Yes [X] No
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? [ ] Yes [X] No
Manufacturer's Name
Type Model No.
Diam. Slot Size Set from ft. to ft.
Diam. Slot Size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level.
Was a pump test made? [ ] Yes [X] No If yes, by whom?
Flow: gal/min. with ft. drawdown after hrs.
Air test 25 gal/min. with drill stem at 90 ft. 1 hrs.
Ballor test gal/min. with ft. drawdown after hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Special standards: Yes [ ] No [X]
Well seal—Material used CEMENT
Well sealed from land surface to 19 ft.
Diameter of well bore to bottom of seal 1.0 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 4 sacks
How was cement grout placed? PUMPED BOTTOM UP
Was pump installed? Type HP Depth ft.
Was a drive shoe used? [ ] Yes [X] No Flugs Size location ft.
Did any strata contain unusable water? [ ] Yes [X] No
Type of Water? depth of strata
Method of sealing strata off
Was well gravel packed? [ ] Yes [X] No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County LANE Driller's well number
NW 1/4 NW 1/4 Section 10 T. 18S R. 4W W.M.
Tax Lot # Lot Blk Subdivision
Address at well location: BAILEY HILL RD.

(11) WATER LEVEL: Completed well.

Depth at which water was first found 85 ft.
Static level 20 ft. below land surface. Date 6/1/84
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 6
Depth drilled 90 ft. Depth of completed well 90 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

Table with columns: MATERIAL, From, To, SWL. Rows include BROWN CLAY, YELLOW CLAY, BLUE ROCK, GRAY ROCK, BLUE ROCK.

Work started 5/31 1984 Completed 6/1 1984
Date well drilling machine moved off of well 6/1 1984

(unbonded) Water Well Constructor Certification (if applicable):
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
(Signed) Date, 1984

Bonded Water Well Constructor Certification:
Bond 57403682 Issued by: TRANSAMERICAN
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name FRANK WILSON DRILLING
Address 1325 135th SPINFIELD, ORE
(Signed) Frank Wilson
Water Well Constructor
Date 6/1, 1984

NOTICE TO WATER WELL CONSTRUCTOR
The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT,
SALEM, OREGON 97310
within 30 days from the date of well completion.

SP-45292-000

**WATER WELL REPORT**  
STATE OF OREGON

#9 - Material used was Cement  
per WWC 5/11/83 JCB

State Well No. 1854W-106

State Permit No. LANIE 16992

PLEASE TYPE or PRINT IN INK

**(1) OWNER:**

Name Mel Purvis Purvis Real Estate  
Address 1754 W. 11th Suite 11  
City Eugene State Oregon

**(2) TYPE OF WORK (check):**

New Well  Deepening  Reconditioning  Abandon

If abandonment, describe material and procedure in Item 12.

**(3) TYPE OF WELL:**

Rotary Air  Drive  Domestic  Industrial  Municipal   
 Rotary Mud  Dog  Irrigation  Test Well  Other   
 Bored  Thermal  Withdrawal  Reinjection

**(4) PROPOSED USE (check):**

**(5) CASING INSTALLED:** Steel  Plastic   
 Threaded  Welded

6" Diam. from +1 ft. to 50 ft. Gauge 250

**LINER INSTALLED:**

Diam. from ft. to ft. Gauge

**(6) PERFORATIONS:** Perforated?  Yes  No

Type of perforator used  
 Size of perforations in. by in.  
 perforations from ft. to ft.  
 perforations from ft. to ft.  
 perforations from ft. to ft.

**(7) SCREENS:** Well screen installed?  Yes  No

Manufacturer's Name  
 Type Model No.  
 Diam. Slot Size Set from ft. to ft.  
 Diam. Slot Size Set from ft. to ft.

**(8) WELL TESTS:** Drawdown is amount water level is lowered below static level

Is a pump test made?  Yes  No. If yes, by whom?  
 Field gal/min. with ft. drawdown after hrs.  
 Air test 10 gal/min. with drill stem at 75 ft. 1 hrs.  
 Bailor test gal/min. with ft. drawdown after hrs.  
 Artesian flow g.p.m.  
 Temperature of water 52° Depth artesian flow encountered ft.

**(9) CONSTRUCTION:** Special standards: Yes  No

Well seal—Material used Bentonite  
 Well sealed from land surface to 50 ft.  
 Diameter of well bore to bottom of seal 10 in.  
 Diameter of well bore below seal 6 in.  
 Number of sacks of cement used in well seal 15 sacks  
 How was cement grout placed? Method #177  
 Was pump installed? Type HP Depth ft.  
 Was a drive shoe used?  Yes  No Plugs Size: location ft.  
 Did any strata contain unusable water?  Yes  No  
 Type of Water? depth of strata  
 Method of sealing strata off  
 Was well gravel packed?  Yes  No Size of gravel: ft.  
 Gravel placed from ft. to ft.

**(10) LOCATION OF WELL:**

County Lane Driller's well number 1108-650 CP  
 W. NW W. Section 10 T. 18 R. 4W W.M.  
 Tax Lot # 501 Lot - Blk. Subdivision  
 Address at well location: Badley Hill Road

**(11) WATER LEVEL: Completed well.**

Depth at which water was first found 70 ft.  
 Static level 30 ft. below land surface. Date 5/3/83  
 Artesian pressure lbs. per square inch. Date

**(12) WELL LOG:** Diameter of well below casing 6"

Depth drilled 100 ft. Depth of completed well 100 ft.  
 Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Top Soil	0	3	
Blue Clay	3	6	
Yellow Clay	6	21	
Brown Clay	21	42	
Blue Shale	42	90	30
Brown Shale	90	100	30

**RECEIVED**

MAY 9 1983

WATER RESOURCES DEPT.  
SALEM, OREGON

Work started 5/2/ 19 83 Completed 5/3/ 19 83  
 Date well drilling machine moved off of well 5/4/ 19 83

**(unbonded) Water Well Constructor Certification (if applicable):**

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.  
 [Signed] James J. Carter Date 5/4/83

**Bonded Water Well Constructor Certification:**

Bond U3-66353 Issued by: United Pacific  
 (number) (Surety Company Name)  
 This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  
 Name CARTER'S DRILLING & PUMP SERVICE  
 Address P.O. Box 46 Springfield, Oregon 97153  
 [Signed] James J. Carter Water Well Constructor  
 Date 5/4/ 19 83

NOTICE TO WATER WELL CONSTRUCTOR  
 The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT,  
 SALEM, OREGON 97310  
 within 30 days from the date of well completion.

SP-45292-650



NOTICE TO WATER WELL CONTRACTOR  
The original and first copy of this report are to be filed with the

**RECEIVED**

**WATER WELL REPORT**

WATER RESOURCES DEPARTMENT  
SALEM, OREGON 97310  
MAR 08 1979 STATE OF OREGON  
WATER RESOURCES DEPT.  
SALEM, OREGON

State Well No. 18s/4w-10  
State Permit No. LAANE 10094

(1) OWNER:  
Name Mr. Roy Duncan #1  
Address 1681 West 7th Street  
Eugene, OR 97402

(2) TYPE OF WORK (check):  
New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL: (4) PROPOSED USE (check):  
Rotary  Driven  Domestic  Industrial  Municipal   
Cable  Jetted  Irrigation  Test Well  Other   
Dug  Bored

CASING INSTALLED: Threaded  Welded   
" Diam. from See Log ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_

PERFORATIONS: Perforated?  Yes  No.  
Type of perforator used \_\_\_\_\_  
Size of perforations in. by in.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(7) SCREENS: Well screen installed?  Yes  No  
Manufacturer's Name \_\_\_\_\_  
Type \_\_\_\_\_ Model No. \_\_\_\_\_  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level  
Was a pump test made?  Yes  No If yes, by whom?  
Yield: \_\_\_\_\_ gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
Well output may fluctuate \_\_\_\_\_  
Baller test \*\*\*\*\* hrs.  
Artesian flow See Well Log  
Temperature of water \_\_\_\_\_ Depth artesian flow encountered \_\_\_\_\_ ft.

(9) CONSTRUCTION: Well seal—Material used See Well Log  
Well sealed from land surface to \_\_\_\_\_ ft.  
Diameter of well bore to bottom of seal \_\_\_\_\_ in.  
Diameter of well bore below seal \_\_\_\_\_ in.  
Number of sacks of cement used in well seal \_\_\_\_\_ sacks  
How was cement grout placed? \_\_\_\_\_  
Was a drive shoe used?  Yes  No Plugs \_\_\_\_\_ Size: location \_\_\_\_\_ ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? \_\_\_\_\_ depth of strata \_\_\_\_\_  
Method of sealing strata off \_\_\_\_\_  
Was well gravel packed?  Yes  No Size of gravel: \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(10) LOCATION OF WELL:  
County Lane Driller's well number 7922  
\_\_\_\_\_ Section 10 T. 18s R. 4w W.M.  
Bearing and distance from section or subdivision corner \_\_\_\_\_

(11) WATER LEVEL: Completed well.  
Depth at which water was first found 125 - 1 1/2 gpm ft.  
Static level -0- ft. below land surface. Date 2-28-79  
Artesian pressure \_\_\_\_\_ lbs. per square inch. Date \_\_\_\_\_

(12) WELL LOG: Diameter of well below casing 6"  
Depth drilled 207 ft. Depth of completed well -0- ft.  
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Gravel Driveway	0	1	
Light Brown Clay & Weathered Sandstone	1	28	
Blue Gray Sandstone	28	207	
Well Bore filled with cement			

Work started 2-27-79 19 \_\_\_\_\_ Completed 2-28-79 19 \_\_\_\_\_  
Date well drilling machine moved off of well 2-28-79 19 \_\_\_\_\_

Drilling Machine Operator's Certification:  
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.  
[Signed] Mark Christensen Date 2-28-79 19 \_\_\_\_\_  
(Drilling Machine Operator)  
Drilling Machine Operator's License No. 9

Water Well Contractor's Certification:  
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  
Name Mark Christensen (Type or print)  
(Person, firm or corporation)  
Address 33132 Coleman Road, Eugene, OR 97401  
[Signed] Mark Christensen (Water Well Contractor)  
Contractor's License No. 97 Date 2-28-79 19 \_\_\_\_\_



NOTICE TO WATER WELL CONTRACTOR  
The original and first copy of this report  
are to be filed with the

WATER RESOURCES DEPARTMENT,  
SALEM, OREGON 97310  
within 30 days from the date  
of well completion.

**WATER WELL REPORT**

STATE OF OREGON

(Please type or print)

(Do not write above this line)

State Well No.

18S/4W-10

State Permit No.

LANE 16975

**RECEIVED**

DEC 21 1977

(1) OWNER:  
Name Don Dealy WATER RESOUR. DEPT.  
Address 3055 Bailey Hill Rd, Eugene, Oregon

(2) TYPE OF WORK (check):  
New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 11.

(3) TYPE OF WELL: (4) PROPOSED USE (check):  
Rotary  Driven  Domestic  Industrial  Municipal   
Cable  Jetted  Irrigation  Test Well  Other   
Dug  Bored

CASING INSTALLED:  
Diam. from +1 ft. to 47 ft. Gage 250  
Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_  
Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_

PERFORATIONS: Perforated?  Yes  No.  
Type of perforator used \_\_\_\_\_  
Size of perforations in. by \_\_\_\_\_ in.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(7) SCREENS: Well screen installed?  Yes  No  
Manufacturer's Name \_\_\_\_\_  
Type \_\_\_\_\_ Model No. \_\_\_\_\_  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level  
Was a pump test made?  Yes  No If yes, by whom?  
Yield: \_\_\_\_\_ gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
\_\_\_\_\_ gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
Ballor test 30 gal./min. with 60 ft. drawdown after 1 hrs.  
Artesian flow \_\_\_\_\_ g.p.m.  
Temperature of water \_\_\_\_\_ Depth artesian flow encountered \_\_\_\_\_ ft.

(9) CONSTRUCTION:  
Well seal—Material used Cement  
Well sealed from land surface to 45 ft.  
Diameter of well bore to bottom of seal 10 in.  
Diameter of well bore below seal 6 in.  
Number of sacks of cement used in well seal 32 sacks  
How was cement grout placed? Slurry poured from the top.

Was a drive shoe used?  Yes  No Plugs \_\_\_\_\_ Size: location \_\_\_\_\_ ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? \_\_\_\_\_ depth of strata \_\_\_\_\_  
Method of sealing strata off \_\_\_\_\_  
Was well gravel packed?  Yes  No Size of gravel: \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(10) LOCATION OF WELL:  
County Lane Driller's well number \_\_\_\_\_  
1/4 Section 10 T. 18S R. 4W W.M.  
Bearing and distance from section or subdivision corner \_\_\_\_\_

(11) WATER LEVEL: Completed well.  
Depth at which water was first found 52 ft.  
Static level 30 ft. below land surface. Date 10/11/77  
Artesian pressure \_\_\_\_\_ lbs. per square inch. Date \_\_\_\_\_

(12) WELL LOG: Diameter of well below casing 6 ft.  
Depth drilled 97 ft. Depth of completed well 97 ft.  
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Topsoil	0	2	
Clay with sand	2	12	
Brown sandstone	12	32	
Brown & blue sandstone	32	42	
Blue sandstone	42	62	30'
Gray sandstone	62	87	
Gray sandstone (very soft)	87	94	
Red clay stone	94	97	30'

Work started 10/10 1977 Completed 10/12 1977  
Date well drilling machine moved off of well 10/12 1977

Drilling Machine Operator's Certification:  
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.  
[Signed] Carl Petcher Date 12/2, 1977  
(Drilling Machine Operator)  
Drilling Machine Operator's License No. 1024

Water Well Contractor's Certification:  
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  
Fitcher Pump & Drilling Company  
Name \_\_\_\_\_ (Person, firm or corporation) (Type or print)  
Address 150 River Ave., Eugene, Oregon 97404  
[Signed] Carl Petcher Water Well Contractor  
Contractor's License No. 494 Date 12/2, 1977

**NOTICE TO WATER WELL CONTRACTOR**

The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

WATER WELL REPORT  
STATE OF OREGON  
(Please type or print)  
Do not write above this line

**RECEIVED**  
MAR 10 1969  
STATE ENGINEER LANE 16996  
SALEM, OREGON

**RECEIVED**  
FEB 17 1969  
STATE ENGINEER  
SALEM, OREGON

(1) OWNER:  
SALEM, OREGON  
Name GERALD GILBERT  
Address 933 PEARL EUGENE

(2) TYPE OF WORK (check):  
New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL: (4) PROPOSED USE (check):  
Rotary  Driven  Domestic  Industrial  Municipal   
Cable  Jetted  Irrigation  Test Well  Other   
Dug  Bored

CASING INSTALLED: Threaded  Welded   
6" Diam. from 4 3/4 ft. to 29 1/2 ft. Gage 1.25  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_

PERFORATIONS: Perforated?  Yes  No.  
Type of perforator used \_\_\_\_\_  
Size of perforations in. by in.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(7) SCREENS: Well screen installed?  Yes  No  
Manufacturer's Name \_\_\_\_\_ Model No. \_\_\_\_\_  
Type \_\_\_\_\_  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(8) WATER LEVEL: Completed well.  
Static level 147 ft. below land surface Date 4-5-68  
Man pressure \_\_\_\_\_ lbs. per square inch Date \_\_\_\_\_

(9) WELL TESTS: Drawdown is amount water level is lowered below static level  
Was a pump test made?  Yes  No If yes, by whom?  
Yield: 50 gal./min. with AIR LIFT drawdown after 1 hrs.

Baller test gal./min. with ft. drawdown after hrs.  
Artesian flow g.p.m. Date \_\_\_\_\_  
Temperature of water \_\_\_\_\_ Was a chemical analysis made?  Yes  No

(10) CONSTRUCTION:  
Well seal—Material used CEMENT GROUT  
Depth of seal 28 1/2 ft.  
Diameter of well bore to bottom of seal 9 5/8 in.  
Were any loose strata cemented off?  Yes  No Depth \_\_\_\_\_  
Was a drive shoe used?  Yes  No  
Did any strata contain unusable water?  Yes  No  
Type of water? \_\_\_\_\_ depth of strata \_\_\_\_\_  
Method of sealing strata off \_\_\_\_\_  
Was well gravel packed?  Yes  No Size of gravel: \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(11) LOCATION OF WELL:  
County LANE Driller's well number \_\_\_\_\_  
1/4 Section 10 T. 18 R. 4 W. W.M. \_\_\_\_\_  
Bearing and distance from section or subdivision corner \_\_\_\_\_

(12) WELL LOG: Diameter of well below casing 6  
Depth drilled 250 ft. Depth of completed well 250 ft.  
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
TOP SOIL	0	1	
W SS. TAN	1	3	
W SS. BRN	3	23	
BL SS	23	97	
BL GRN SS	97	250	

Work started 4-1 1968 Completed 4-5 1968  
Date well drilling machine moved off of well 4-5 1968

Drilling Machine Operator's Certification:  
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.  
[Signed] Mark H. Christensen Date 4-5 1968  
(Drilling Machine Operator)

Drilling Machine Operator's License No. 9 4 512

Water Well Contractor's Certification:  
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  
NAME MART CHRISTENSEN  
(Person, firm or corporation) (Type or print)  
Address 3550 W 18, EUGENE  
[Signed] Mark H. Christensen  
(Water Well Contractor)  
Contractor's License No. 97 Date 4-5 1968





NOTICE TO WATER WELL CONTRACTOR  
The original and first copy of this report  
are to be filed with the

**WATER WELL REPORT**

WATER RESOURCES DEPARTMENT.  
SALEM, OREGON 97310  
within 30 days from the date  
of well completion.

STATE OF OREGON

State Well No.

State Permit No.

185/4w-70

LANE 17000

**RECEIVED**

(Please type or print)  
(If handwritten, write above this line.)

(1) OWNER: JUL - 5 1977  
Name Mr. Joe Anselmo WATER RESOURCES DEPT.  
Address 2820 Chuckanut SALEM, OREGON  
Eugene, OR

(2) TYPE OF WORK (check):  
New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL: (4) PROPOSED USE (check):  
Rotary  Driven  Domestic  Industrial  Municipal   
Cable  Jetted  Irrigation  Test Well  Other   
Dug  Bored

(5) CASING INSTALLED: Threaded  Welded   
6" Diam. from 0 ft. to 40 ft. Gage 250  
" Diam. from ft. to ft. Gage  
" Diam. from ft. to ft. Gage

(6) PERFORATIONS: Perforated?  Yes  No.  
Type of perforator used  
Size of perforations in. by in.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.

(7) SCREENS: Well screen installed?  Yes  No  
Manufacturer's Name  
Type Model No.  
Diam. Slot size Set from ft. to ft.  
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level  
Was a pump test made?  Yes  No. If yes, by whom?  
Yield: gal/min. with ft. drawdown after hrs.  
Tested by Air (Est. could fluctuate)  
20 gal/min. with 59 ft. drawdown after 1 hrs.  
Artesian flow g.p.m.  
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:  
Well seal—Material used Cement  
Well sealed from land surface to 79 ft.  
Diameter of well bore to bottom of seal 10 in.  
Diameter of well bore below seal 6 in.  
Number of sacks of cement used in well seal 8 sacks  
How was cement grout placed? Poured

Was a drive shoe used?  Yes  No Plug Size: location ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? depth of strata  
Method of sealing strata off  
Was well gravel packed?  Yes  No Size of gravel:  
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:  
County Lane Driller's well number  
1/4 1/4 Section 10 T. 18S R. 4W W.M.  
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.  
Depth at which water was first found 78 ft.  
Static level 46 ft. below land surface. Date 6/8/77  
Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing 6"  
Depth drilled 105 ft. Depth of completed well 105 ft.  
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Top Soil	0	2	
Brown gray clay	2	24	
Brown cong.	24	34	
Gray sandstone	34	69	
Blue green cong.	69	105	

Work started 6/8 1977 Completed 6/8 1977  
Date well drilling machine moved off of well 6/8 1977

Drilling Machine Operator's Certification:  
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.  
[Signed] M. K. Jones Date 6/8, 1977  
(Drilling Machine Operator)  
Drilling Machine Operator's License No. 702

Water Well Contractor's Certification:  
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  
Name Casey Jones Well Drilling Co., Inc.  
(Person, firm or corporation) (Type or print)  
Address 37115 Immigrant Road, Pleasant Hill, OR  
[Signed] Casey Jones  
(Water Well Contractor)  
Contractor's License No. 559 Date 6/8, 1977









**NOTICE TO WATER WELL CONTRACTOR**

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON within 30 days from the date of well completion.

**RECEIVED**  
**RECEIVED**  
 AUG 10 1972 STATE OF OREGON OCT 24 1972  
 STATE ENGINEER SALEM, OREGON

State Well No. 185/4W-1A  
 Permit No. LANE 178034

**(1) OWNER:**

Name Douglas Capps  
 Address Rt 3 Box 189E  
Eugene, Oregon

**(2) TYPE OF WORK (check):**

New Well  Deepening  Reconditioning  Abandon   
 If abandonment, describe material and procedure in item 12.

**(3) TYPE OF WELL:**

Rotary  Driven  Domestic  Industrial  Municipal   
 Cable  Jetted  Dug  Bored  Irrigation  Test Well  Other

**(4) PROPOSED USE (check):**

**(5) CASING INSTALLED:**

Threaded  Welded   
6 " Diam. from 0 ft. to 20 ft. Gage # 250  
5 " Diam. from 0 ft. to 95 ft. Gage # 10  
 " Diam. from " ft. to " ft. Gage

**(6) PERFORATIONS:**

Perforated?  Yes  No.  
 Type of perforator used \_\_\_\_\_  
 Size of perforations in. by in.  
 \_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
 \_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
 \_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

**(7) SCREENS:**

Well screen installed?  Yes  No  
 Manufacturer's Name \_\_\_\_\_  
 Type \_\_\_\_\_ Model No. \_\_\_\_\_  
 Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
 Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

**(8) WELL TESTS:**

Drawdown is amount water level is lowered below static level  
 Was a pump test made?  Yes  No If yes, by whom?  
 Yield: \_\_\_\_\_ gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
 \_\_\_\_\_ tested with air; estimate could fluctuate  
 \_\_\_\_\_ test 9 gal./min. with 80 ft. drawdown after 1 hrs.  
 Artesian flow \_\_\_\_\_ s.p.m.  
 \_\_\_\_\_ temperature of water \_\_\_\_\_ Depth artesian flow encountered \_\_\_\_\_ ft.

**(9) CONSTRUCTION:**

Well seal—Material used Cement grout  
 Well sealed from land surface to 18 ft.  
 Diameter of well bore to bottom of seal 10 in.  
 Diameter of well bore below seal 6 in.  
 Number of sacks of cement used in well seal 5 sacks  
 Number of sacks of bentonite used in well seal \_\_\_\_\_ sacks  
 Brand name of bentonite: \_\_\_\_\_  
 Number of pounds of bentonite per 100 gallons of water \_\_\_\_\_ lbs./100 gals.  
 Was a drive shoe used?  Yes  No Plugs \_\_\_\_\_ Size: location \_\_\_\_\_ ft.  
 Did any strata contain unusable water?  Yes  No  
 Type of water? \_\_\_\_\_ depth of strata \_\_\_\_\_  
 Method of sealing strata off \_\_\_\_\_  
 Was well gravel packed?  Yes  No Size of gravel: \_\_\_\_\_  
 Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

**(10) LOCATION OF WELL:**

County Lane Driller's well number \_\_\_\_\_  
 1/4 Section 11 T. 14 S. R. 4 W. W.M.  
 Bearing and distance from section or subdivision corner  
Sec-11 Township 18 S

**(11) WATER LEVEL: Completed well.**

Depth at which water was first found 44 ft.  
 Static level 15 ft. below land surface. Date 8/5/72  
 Artesian pressure \_\_\_\_\_ lbs. per square inch. Data \_\_\_\_\_

**(12) WELL LOG:**

Diameter of well below casing 6"  
 Depth drilled 95 ft. Depth of completed well 95 ft.  
 Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Black clay	0'	9'	
blue claystone	9	24	
gray claystone	24	29	
blue claystone	29	48	
blue sandstone	48	63	
blue claystone	63	70	
light blue sandstone	70	76	
blue claystone	76	95	

Work started 8/5/72 12 Completed 8/7/72 19  
 Date well drilling machine moved off of well 8/7/72 19

**Drilling Machine Operator's Certification:**  
 This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.  
 [Signed] Casey J. Jones Date Aug. 8, 1972.  
 (Drilling Machine Operator)

**Water Well Contractor's Certification:**  
 This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  
 Name CASEY JONES WELL DRILLING CO INC  
 (Person, firm or corporation) (Type or print)  
 Address Rt 8 Box 695 Pleasant Hill, Oregon  
 [Signed] Casey J. Jones  
 (Water Well Contractor)  
 Contractor's License No. 559 Date August 8 1972

NOTICE TO WATER WELL CONTRACTOR  
The original and first copy  
of this report are to be  
filed with the  
STATE ENGINEER, SALEM, OREGON 97310  
within 30 days from the date  
of well completion.

WATER WELL REPORT RECEIVED LANE 17005  
STATE OF OREGON (Please type or print) JUN 1 1976 State Permit No. 183/4W-11  
(Do not write above this line)  
WATER RESOURCES DEPT.

(1) OWNER:

Name S. GILBERT CUDEBACK  
Address 2100 Keith Way  
Eugene, OR 97401

(2) TYPE OF WORK (check):

New Well  Despensing  Reconditioning  Abandon   
If abandonment, describe material and procedure in item 11.

(3) TYPE OF WELL:

Rotary  Driven  Domestic  Industrial  Municipal   
Cable  Jetted  Irrigation  Test Well  Other   
Dug  Bored

(4) PROPOSED USE (check):

CASING INSTALLED: Threaded  Welded   
6" Diam. from 2 ft. to 100 ft. Gage 250  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_

PERFORATIONS:

Perforated?  Yes  No.  
Type of perforator used \_\_\_\_\_  
Size of perforations \_\_\_\_\_ in. by \_\_\_\_\_ in.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(7) SCREENS:

Well screen installed?  Yes  No  
Manufacturer's Name \_\_\_\_\_ Model No. \_\_\_\_\_  
Type \_\_\_\_\_ Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level.  
Was a pump test made?  Yes  No If yes, by whom? \_\_\_\_\_  
Yield: \_\_\_\_\_ gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
\_\_\_\_\_ gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
\_\_\_\_\_ gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
Bailer test 12 gal./min. with 225 ft. drawdown after 1 hrs.  
Artesian flow \_\_\_\_\_ g.p.m.  
Temperature of water 55° Depth artesian flow encountered \_\_\_\_\_ ft.

(9) CONSTRUCTION:

Well seal - Material used CEMENT GROUT  
Well sealed from land surface to 30 ft.  
Diameter of well bore to bottom of seal 10 in.  
Diameter of well bore below seal 6 in.  
Number of sacks of cement used in well seal 15 sacks  
Number of sacks of bentonite used in well seal 0 sacks  
Brand name of bentonite \_\_\_\_\_  
Number of pounds of bentonite per 100 gallons of water \_\_\_\_\_ lbs./100 gals.  
Was a drive shoe used?  Yes  No Plug \_\_\_\_\_ Size: location \_\_\_\_\_ ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? \_\_\_\_\_ depth of strata \_\_\_\_\_  
Method of sealing strata off \_\_\_\_\_  
Was well gravel packed?  Yes  No Size of gravel: \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(10) LOCATION OF WELL:

County LANE Driller's well number 264  
S.E. & N.E. 1/4 Section 11 T. 18S R. 4 W. W.M. \_\_\_\_\_  
Bearing and distance from section or subdivision corner \_\_\_\_\_

(11) WATER LEVEL: Completed well.

Depth at which water was first found 32 ft.  
Static level 18 ft. below land surface. Date 5/21/76  
Artesian pressure \_\_\_\_\_ lbs. per square inch. Date \_\_\_\_\_

(12) WELL LOG:

Diameter of well below casing 6"  
Depth drilled 255 ft. Depth of completed well 255 ft.  
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Brown Clay	0	19	
Blue Claystone	19	30	
Dark Blue-Grey Basalt	30	105	18'
Red-Brown Claystone	105	140	18'
Blue Claystone	140	150	18'
Grey Claystone	150	155	18'
Light Blue Claystone	155	167	18'
Brown Claystone	167	190	18'
Blue Sandstone	190	255	18'

Work started 5 - 10 1976 Completed 5 - 21 1976  
Date well drilling machine moved off of well 5 - 21 1976

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.  
[Signed] Pauland Corp. Date 5-21-76  
(Drilling Machine Operator) License No. 512

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  
Name GUS STORES LOGGING & WELL DRILLING  
(Person, firm or corporation) (Type or print)  
Address 5585 West 11th Ave., Eugene, OR, 97402  
[Signed] Pauland Corp.  
(Water Well Contractor) License No. 578 Date 5-26-1976





APR 24 1989

LANE

17081

B/H/W/K/ab

(START CARD) # 9493

STATE OF OREGON  
WATER WELL REPORT  
(as required by ORS 537.765)

WATER RESOURCES DEPT.  
SALEM, OREGON

(1) OWNER: Well Number: \_\_\_\_\_  
Name JERRY LANDAUER  
Address 1016 R. ST. ART. C  
City SPRINGFIELD State OR Zip 97477

(2) TYPE OF WORK:  
 New Well  Deepen  Recondition  Abandon

(3) DRILL METHOD  
 Rotary Air  Rotary Mud  Cable  
 Other \_\_\_\_\_

(4) PROPOSED USE:  
 Domestic  Community  Industrial  Irrigation  
 Thermal  Injection  Other \_\_\_\_\_

(5) BORE HOLE CONSTRUCTION:  
Special Construction approval Yes  No  Depth of Completed Well 160 ft.  
Explosives used  Yes  No  Type \_\_\_\_\_ Amount \_\_\_\_\_

HOLE SEAL

Diameter	From	To	Material	From	To	Amount secks or pounds
10	0	40	CEMENT	0	40	13
6	40	160				

How was seal placed: Method  A  B  C  D  E  
 Other \_\_\_\_\_  
Backfill placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Material \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Size of gravel \_\_\_\_\_

(6) CASING/LINER:

Diameter	From	To	Gauge	Steel	Plastic	Welded	Threaded
Casing: 6	1	40	250	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Liner: 4 1/2	30	160	PR26	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

Final location of shoe(s) \_\_\_\_\_

(7) PERFORATIONS/SCREENS:  
 Perforations Method SAW  
 Screens Type \_\_\_\_\_ Material \_\_\_\_\_

From	To	Slot size	Number	Diameter	Tel./pipe size	Casing	Liner
140	155	18	75	4 1/2		<input type="checkbox"/>	<input checked="" type="checkbox"/>

(8) WELL TESTS: Minimum testing time is 1 hour  
 Pump  Bailor  Air  Artesian  
Yield gal/min 20 Drawdown 160 Drill stem at \_\_\_\_\_ Time 1 hr.

Temperature of water \_\_\_\_\_ Depth Artesian Flow Found \_\_\_\_\_  
Was a water analysis done?  Yes By whom \_\_\_\_\_  
Did any strata contain water not suitable for intended use?  Too little  
 Salty  Muddy  Odor  Colored  Other \_\_\_\_\_  
Depth of strata: \_\_\_\_\_

(9) LOCATION OF WELL by legal description:  
County LANE Latitude \_\_\_\_\_ Longitude \_\_\_\_\_  
Township 18 S N or S, Range 4 W E or W, WM.  
Section 14 NW 4 NE 4  
Tax Lot \_\_\_\_\_ Lot \_\_\_\_\_ Block \_\_\_\_\_ Subdivision \_\_\_\_\_  
Street Address of Well (or nearest address) 26514 LOGANE HWY  
EUGENE, OR.

(10) STATIC WATER LEVEL:  
20 ft. below land surface. Date 4/20/89  
Artesian pressure \_\_\_\_\_ lb. per square inch. Date \_\_\_\_\_

(11) WATER BEARING ZONES:

Depth at which water was first found 70

From	To	Estimated Flow Rate	SWL
69	70	4	20'
150	151	16	20'

(12) WELL LOG: Ground elevation \_\_\_\_\_

Material	From	To	SWL
S&K	0	2	
BROWN CLAY	2	16	
YELLOW CLAY	16	24	
BLUE CLAY	24	32	
BLUE ROCK	32	160	20'

Date started 4/18/89 Completed 4/29/89

(unbonded) Water Well Constructor Certification:  
I certify that the work I performed on the construction, alteration, or abandonment of this well is in compliance with Oregon well construction standards. Materials used and information reported above are true to my best knowledge and belief.

Signed \_\_\_\_\_ WWC Number \_\_\_\_\_  
Date \_\_\_\_\_

(bonded) Water Well Constructor Certification:  
I accept responsibility for the construction, alteration, or abandonment work performed on this well during the construction dates reported above. All work performed during this time is in compliance with Oregon well construction standards. This report is true to the best of my knowledge and belief.

Signed Frank Wilson WWC Number 562  
Date 4/21/89



RECEIVED

STATE OF OREGON  
WATER WELL REPORT  
(as required by ORS 837.766)

SEP 24 1987

-18s/4w-14  
LANE 17023

(1) OWNER:  
Name Rudy Powell Well Number: \_\_\_\_\_  
Address 26721 Pickens Rd. WATER RESOURCES DEPT.  
City Eugene State Or. Zip 97402 SALEM, OREGON

(9) LOCATION OF WELL by legal description:  
County Lane Latitude \_\_\_\_\_ Longitude \_\_\_\_\_  
Township 18S Nor S, Range 4W E or W, WM.  
Section 14 \_\_\_\_\_ W \_\_\_\_\_ W  
Tax Lot 4100 Lot \_\_\_\_\_ Block \_\_\_\_\_ Subdivision \_\_\_\_\_  
Street Address of Well (or nearest address) 86433 Lorane Hwy.  
Eugene, Or.

(2) TYPE OF WORK:  
 New Well  Deepen  Recondition  Abandon

(3) DRILL METHOD  
 Rotary Air  Rotary Mud  Cable  
 Other \_\_\_\_\_

(4) PROPOSED USE:  
 Domestic  Community  Industrial  Irrigation  
 Thermal  Injection  Other \_\_\_\_\_

(5) BORE HOLE CONSTRUCTION:  
Special Construction approval Yes  No   
Depth of Completed Well 385 ft.  
Explosives used   Type \_\_\_\_\_ Amount \_\_\_\_\_

(10) STATIC WATER LEVEL:  
100' ft. below land surface. Date 8-28-87  
Artesian pressure \_\_\_\_\_ lb. per square inch. Date \_\_\_\_\_

HOLE SEAL

meter	From	To	Material	From	To	Amount
10"	0	58	Cement	0	58	15 sacks
6"	58	385				

(11) WATER BEARING ZONES:  
Depth at which water was first found 350'

From	To	Estimated Flow Rate	SWL
350'	355'	7 1/2 gpm	100'

How was seal placed: Method  A  B  C  D  E  
 Other \_\_\_\_\_  
Backfill placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Material \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Size of gravel \_\_\_\_\_

(12) WELL LOG: Ground elevation \_\_\_\_\_

(6) CASING/LINER:

Diameter	From	To	Gauge	Steel	Plastic	Welded	Threaded
Casing: 6"	+1	59	.250	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Liner: 4 1/2"	0	385	PVC	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Material	From	To	SWL
Topsoil	0	1	
Brown Clay	1	27	
Brown Gray Green soft Cong.	27	50	
Gray Green Cong.	50	78	
Gray Sandstone	78	133	
Basalt	133	138	
Light Green Sandstone soft	138	223	
Gray Green Sandstone	223	255	
Gray Blue Green Cong.	255	330	
Brown Claystone	330	344	
Gray Green Sandy Cong.	344	385	100'

(7) PERFORATIONS/SCREENS:  
 Perforations Method SAW  
 Screens Type \_\_\_\_\_ Material \_\_\_\_\_

From	To	Slot size	Number	Diameter	Tota/pipe size	Casing	Liner
285	385	2"	1000	1/8"	4 1/2"	<input type="checkbox"/>	<input checked="" type="checkbox"/>

Date started 8-27-87 Completed 8-28-87

(8) WELL TESTS: Minimum testing time is 1 hour  
 Pump  Bailer  Air  Flowing Artesian  
Yield gal/min 7 1/2 gpm Drawdown 285 Drill stem at 385 Time 1 hr.

(unbonded) Water Well Constructor Certification:  
I certify that the work I performed on the construction, alteration, or abandonment of this well is in compliance with Oregon well construction standards. Materials used and information reported above are true to my best knowledge and belief.

Signed Bob Murphy WWC Number 1744  
Date 8-28-87

Temperature of water \_\_\_\_\_ Depth Artesian Flow Found \_\_\_\_\_  
Was a water analysis done?  Yes By whom \_\_\_\_\_  
Did any strata contain water not suitable for intended use?  Too little  
 Salty  Murky  Odor  Colored  Other not tested  
Depth of strata: \_\_\_\_\_

(bonded) Water Well Constructor Certification:  
I accept responsibility for the construction, alteration, or abandonment work performed on this well during the construction dates reported above. all work performed during this time is in compliance with Oregon well construction standards. This report is true to the best of my knowledge and belief.

Signed Casey L. Jones WWC Number 559  
Date 8-28-87

STATE OF OREGON  
WATER WELL REPORT  
(as required by ORS 537.765)

RECEIVED

JAN 30 1985

WATER RESOURCES DEPARTMENT

LANE

17024

18<sup>th</sup> 4<sup>th</sup> W-14  
Record

SALEM, OREGON

(for official use only)

(1) OWNER:  
Name Bob Engelstad  
Address P.O. Box 10202  
City Eugene State OR

(2) TYPE OF WORK (check):  
New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL: (4) PROPOSED USE (check):  
Rotary Air  Drilled  Domestic  Industrial  Municipal   
Rotary Mud  Dug  Irrigation  Thermal  Withdrawal  ReInjection   
Cable  Bored  Other: Piezometric  Grounding  Test

(5) CASING INSTALLED: Steel  Plastic   
Threaded  Welded   
"Diam. from EXISTING ft. to \_\_\_\_\_ ft. Gauge \_\_\_\_\_  
"Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gauge \_\_\_\_\_

LINER INSTALLED: Steel  Plastic   
Threaded  Welded   
"Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gauge \_\_\_\_\_

(6) PERFORATIONS: Perforated?  Yes  No  
Size of perforations \_\_\_\_\_ in. by \_\_\_\_\_ in.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(7) SCREENS: Well screen installed?  Yes  No  
Manufacturer's Name \_\_\_\_\_  
Type \_\_\_\_\_ Model No. \_\_\_\_\_  
Diam. \_\_\_\_\_ Slot Size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Diam. \_\_\_\_\_ Slot Size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level  
Was a pump test made?  Yes  No If yes, by whom? Chris Christensen  
\_\_\_\_\_ gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
Air test \_\_\_\_\_ gal./min. with drill stem at \_\_\_\_\_ ft. \_\_\_\_\_ hrs.  
Boiler test \_\_\_\_\_ gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
Arterian flow \_\_\_\_\_ g.p.m.  
Temperature of water \_\_\_\_\_ Depth artesian flow encountered \_\_\_\_\_ ft.

(9) CONSTRUCTION: Special standards: Yes  No   
Well seal—Material used \_\_\_\_\_  
Well sealed from land surface to \_\_\_\_\_ ft.  
Diameter of well bore to bottom of seal \_\_\_\_\_ in.  
Diameter of well bore below seal \_\_\_\_\_ in.  
Amount of sealing material \_\_\_\_\_ sacks  pounds   
How was cement group placed \_\_\_\_\_

Was pump installed? \_\_\_\_\_ Type \_\_\_\_\_ HP \_\_\_\_\_ Depth \_\_\_\_\_ ft.  
Was a drive shoe used?  Yes  No Plug \_\_\_\_\_ Size location \_\_\_\_\_ ft.  
Did any strata contain unusable water?  Yes  No  
Type of Water? \_\_\_\_\_ depth of strata \_\_\_\_\_  
Method of sealing strata off \_\_\_\_\_  
Was well gravel packed?  Yes  No Size of gravel: \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(10) LOCATION OF WELL by legal description:  
County LANE W. 1/4 of Section 14 of  
Township 18 S Range 4 W W.M.  
(Township is North or South) (Range is East or West)

Tax Lot \_\_\_\_\_ Lot \_\_\_\_\_ Block \_\_\_\_\_ Subdivision \_\_\_\_\_  
MAILING ADDRESS OF WELL (or nearest address) 86279 Locust  
Way, Eugene

(11) WATER LEVEL OF COMPLETED WELL:  
Depth at which water was first found \_\_\_\_\_ ft.  
Static level 22 ft. below land surface. Date 1/28  
Artesian pressure \_\_\_\_\_ lbs. per square inch. Date \_\_\_\_\_

(12) WELL LOG: Diameter of well below casing \_\_\_\_\_ ft.  
Depth drilled \_\_\_\_\_ ft. Depth of completed well 84 ft.  
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Well Drilled For			
Wayne Weber			
6/24/76 155'			
Well Grouted with			
Cement from 155' to 84'			
Cement Pumped thru casing			
12 sacks cement			

Date work started 1/20/85 /completed 1/28/85  
Date well drilling machine moved off of well \_\_\_\_\_ 19

(unbonded) Water Well Constructor Certification (if applicable):  
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

(Signed) \_\_\_\_\_ Date \_\_\_\_\_, 19

(bonded) Water Well Constructor Certification  
Bond 6627655 issued by: TRAVELERS  
(number) (Surety Company Name)  
On behalf of CHRISTENSEN WELL DRILLING  
(type or print name of Water Well Constructor)

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

(Signed) Paul Christensen U-Prop  
(Water Well Constructor)  
(Dated) 1/27/85

NOTICE TO WATER WELL CONSTRUCTOR  
The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT,  
SALEM, OREGON 97310  
within 30 days from the date of well completion.

SP-46968-690





STATE OF OREGON  
**WATER WELL REPORT**  
 (as required by ORS 537.785)

**RECEIVED**

SEP 27 1984

PLEASE TYPE OR PRINT WATER RESOURCES DEPARTMENT  
 SALEM, OREGON

185/4W-146  
 LANE 17026  
 (for official use only)

**(1) OWNER:**

Name SANDRA HALL  
 Address 86313 Lorana hwy  
 City RIDENR 97105 State Ore

**(2) TYPE OF WORK (check):**

New Well  Deepening  Reconditioning  Abandon   
 If abandonment, describe material and procedure in Item 12.

**(3) TYPE OF WELL:**

Rotary Air  Driven  Domestic  Industrial  Municipal   
 Rotary Mud  Dog  Irrigation  Thermal  Rejection   
 Cable  Bored  Other: Piezometric  Grounding  Test

**(4) CASING INSTALLED:**

Steel  Plastic   
 Threaded  Welded   
 6" Diam. from 1 ft. to 19 ft. Gauge 250  
 " Diam. from ft. to ft. Gauge

**(5) LINER INSTALLED:**

Steel  Plastic   
 Threaded  Welded   
 1 1/2" Diam. from 1 ft. to 360 ft. Gauge 160 psi

**(6) PERFORATIONS:**

Size of perforations 1/8 in. by 1 in. Perforated?  Yes  No  
155 perforations from 60 ft. to 360 ft.  
 perforations from ft. to ft.  
 perforations from ft. to ft.

**(7) SCREENS:**

Well screen installed?  Yes  No  
 Manufacturer's Name \_\_\_\_\_ Model No. \_\_\_\_\_  
 Type \_\_\_\_\_ Diam. \_\_\_\_\_ Slot Size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
 Diam. \_\_\_\_\_ Slot Size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

**(8) WELL TESTS:**

Drawdown is amount water level is lowered below static level  
 Was a pump test made?  Yes  No If yes, by whom?  
 \_\_\_\_\_ gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
 Air test 2 gal./min. with drill stem at 410 ft. 1 hrs.  
 Bailor test \_\_\_\_\_ gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
 Artesian flow \_\_\_\_\_ g.p.m.  
 \_\_\_\_\_ temperature of water \_\_\_\_\_ Depth artesian flow encountered \_\_\_\_\_ ft.

**(9) CONSTRUCTION:**

Special standards: Yes  No   
 Well seal—Material used Cement + 5% Bentonite  
 Well sealed from land surface to \_\_\_\_\_ ft.  
 Diameter of well bore to bottom of seal 10 in.  
 Diameter of well bore below seal 6 in.  
 Amount of sealing material \_\_\_\_\_ sacks  pounds   
 How was cement grout placed? Pumped

Was pump installed? \_\_\_\_\_ Type \_\_\_\_\_ HP \_\_\_\_\_ Depth \_\_\_\_\_ ft.  
 Was a drive shoe used?  Yes  No Plug \_\_\_\_\_ Size location \_\_\_\_\_ ft.  
 Did any strata contain unusable water?  Yes  No  
 Type of Water? \_\_\_\_\_ depth of strata \_\_\_\_\_  
 Method of sealing strata off \_\_\_\_\_  
 Was well gravel packed?  Yes  No Size of gravel \_\_\_\_\_  
 Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

**(10) LOCATION OF WELL by legal description:**

County LANE SW 1/4 NW 1/4 of Section 11 of  
 Township 18 S Range 1 W WM.  
 (Township is North or South) (Range is East or West)  
 Tax Lot \_\_\_\_\_ Lot \_\_\_\_\_ Block \_\_\_\_\_ Subdivision \_\_\_\_\_  
 MAILING ADDRESS OF WELL (or nearest address) \_\_\_\_\_  
Same

**(11) WATER LEVEL OF COMPLETED WELL:**

Depth at which water was first found 130 ft.  
 Static level 28 ft. below land surface. Date 8-21-84  
 Artesian pressure \_\_\_\_\_ lbs. per square inch. Date \_\_\_\_\_

**(12) WELL LOG:**

Diameter of well below casing 6"  
 Depth drilled 115 ft. Depth of completed well 360 ft.  
 Formation: Describe color, texture, grain size and structure of material; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Top soil	0	1	
Brown clay with boulders	1	5	
Dark gray basalt	5	130	
Red sed. rock (crumbling)	130	135	
Gray sed. rock	135	280	
Dark gray basalt	280	310	
Gray sed. rock	310	415	28'

Date work started 8-21-84/completed 8-21-84  
 Date well drilling machine moved off of well 8-21-84

**(unbonded) Water Well Constructor Certification (if applicable):**

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

(Signed) [Signature] Lic. 1335 Date 8-21-84

**(bonded) Water Well Constructor Certification:**

Bond \_\_\_\_\_ Issued by: \_\_\_\_\_ (Surety Company Name)  
 On behalf of DELL PAGE WELL DRILLING INC.  
 (Type or print name of Water Well Constructor)

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

(Signed) [Signature] Lic. 704  
 (Water Well Constructor)

(Dated) Well # 130-84 8-21-84

NOTICE TO WATER WELL CONSTRUCTOR  
 The original and first copy of this report  
 are to be filed with the

WATER RESOURCES DEPARTMENT,  
 SALEM, OREGON 97310  
 within 30 days from the date of well completion.

SP-45306-800

NOTICE TO WATER WELL CONTRACTOR  
The original and first copy of this report  
are to be filed with the

WATER RESOURCES DEPARTMENT,  
SALEM, OREGON 97310  
within 30 days from the date  
of well completion.

WATER WELL REPORT

STATE OF OREGON  
(Please type or print)

(Do not write above this line)

RECEIVED

MAR 27 1984

State Well No.

189/4W-142

WATER RESOURCES DEPT., permit No.

LANE 17007

SALEM, OREGON

(1) OWNER:

Name Will Morningsun  
Address 30900 Blanton Road  
 Eugene, OR 97405

(2) TYPE OF WORK (check):

New Well  Deepening  Reconditioning  Abandon

If abandonment, describe material and procedure in Item 13.

(3) TYPE OF WELL:

Rotary  Driven   
Cable  Jetted   
Dug  Bored

(4) PROPOSED USE (check):

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

CASING INSTALLED:

Threaded  Welded   
6 5/8" Diam. from ±1 ft. to 19 ft. Gage 250  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_

PERFORATIONS:

Perforated?  Yes  No.

Type of perforator used \_\_\_\_\_

Size of perforations in. by \_\_\_\_\_ in.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(7) SCREENS:

Well screen installed?  Yes  No

Manufacturer's Name \_\_\_\_\_  
Type \_\_\_\_\_ Model No. \_\_\_\_\_  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made?  Yes  No If yes, by whom? \_\_\_\_\_  
Yield: \_\_\_\_\_ gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.

Barrier test 1 1/2 gal./min. with MAX. ft. drawdown after 1 hrs.

Artesian flow \_\_\_\_\_ g.p.m.

Temperature of water \_\_\_\_\_ Depth artesian flow encountered \_\_\_\_\_ ft.

(9) CONSTRUCTION:

Well seal—Material used Cement Grout  
Well sealed from land surface to 18 ft.  
Diameter of well bore to bottom of seal 6 in.  
Diameter of well bore below seal 10 in.  
Number of sacks of cement used in well seal 10 sacks  
How was cement grout placed? Pumped

Was a drive shoe used?  Yes  No Plugs \_\_\_\_\_ Size: location \_\_\_\_\_ ft.

Did any strata contain unusable water?  Yes  No

Type of water? \_\_\_\_\_ depth of strata \_\_\_\_\_

Method of sealing strata off \_\_\_\_\_

Was well gravel packed?  Yes  No Size of gravel: \_\_\_\_\_

Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(10) LOCATION OF WELL:

County Lane Driller's well number 605-172  
SE 1/4 NE 1/4 Section 14 T. 18 S. R. 4 W. W.M.

Bearing and distance from section or subdivision corner \_\_\_\_\_

Approx. 750' SSW from NE property corner.

Tax Lot 4008

(11) WATER LEVEL: Completed well.

Depth at which water was first found 40 ft.

Static level 25 ft. below land surface. Date 3/18/84

Artesian pressure \_\_\_\_\_ lbs. per square inch. Date \_\_\_\_\_

(12) WELL LOG:

Diameter of well below casing 6 1/2 in.

Depth drilled 105 ft. Depth of completed well 105 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Clay & boulders	0	4 1/2	
Basalt, hard blue	4 1/2	10	
Basalt, hard blue, fractured	10	15	
Basalt, hard	15	18	
Claystone, soft blue	18	25	
Claystone, soft red	25	29 1/2	
Claystone, bluegray *Harder	29 1/2	39	
Claystone, pink, blue (Fract.)	39	44	Trace
Basalt, fractured, hard	44	54	
Basalt, extremely hard	54	57	
Claystone, bluegray, hard	57	69	
Claystone, blue w/white flecks	69	74	
Claystone, blue, softer	74	81	
Claystone, brown & hard (Fract.)	81	86	
Claystone, brown & blue (Fract.)	86	88	
Claystone, red and brown	88	91	
Basalt, very hard	91	95	
Basalt, red, softer	95	105	

Work started Feb. 18 1984 Completed Mar. 20 1984

Date well drilling machine moved off of well March 20 1984

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

(Signed) John D. Hoed Date Mar. 20, 1984  
(Drilling Machine Operator)

Drilling Machine Operator's License No. 605

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name HOECK WELL DRILLING (Type or print)

Address P.O. BOX 1577, Eugene, OR 97440 (Type or print)

(Signed) John D. Hoed (Water Well Contractor)

Contractor's License No. 605 Date March 20, 1984



**WATER WELL REPORT**  
STATE OF OREGON

**RECEIVED**  
SEP 17 1980

WATER RESOURCES DEPT  
HALEM, OREGON

State Well No. 18/40-14  
State Permit No. LANE 17029

(1) OWNER:  
Name Roger Ostrander  
Address 86141 Lorane Hwy. 97405  
City Eugene, State Oregon

(2) TYPE OF WORK (check):  
New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in item 12.

(3) TYPE OF WELL: (4) PROPOSED USE (check):  
Air  Driven  Domestic  Industrial  Municipal   
Rocky Mud  Dug  Irrigation  Test Well  Other   
Cable  Bored  Thermal  Withdrawal  ReInjection

(5) CASING INSTALLED: Steel  Plastic   
Threaded  Welded   
"Diam. from 1 1/2 ft. to 20 ft. Gauge 250

LINER INSTALLED:  
"Diam. from 4 ft. to 400 ft. Gauge 160 #

(6) PERFORATIONS: Perforated?  Yes  No  
Type of perforator used \_\_\_\_\_  
Size of perforations in. by \_\_\_\_\_ in.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(7) SCREENS: Well screen installed?  Yes  No  
Manufacturer's Name \_\_\_\_\_  
Type \_\_\_\_\_ Model No. \_\_\_\_\_  
Diam. \_\_\_\_\_ Slot Size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Diam. \_\_\_\_\_ Slot Size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level  
Was a pump test made?  Yes  No If yes, by whom? \_\_\_\_\_  
Yield: \_\_\_\_\_ gal/min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
Air test 7 1/2 gal/min. with drill stem at 400 ft. 1 hrs.  
Pump test \_\_\_\_\_ gal/min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
Artesian flow \_\_\_\_\_ g.p.m.  
Temperature of water \_\_\_\_\_ Depth artesian flow encountered \_\_\_\_\_ ft.

(9) CONSTRUCTION: Special standards: Yes  No   
Well seal—Material used Cement Grout  
Well sealed from land surface to 20 ft.  
Diameter of well bore to bottom of seal 10 in.  
Diameter of well bore below seal 6 in.  
Number of sacks of cement used in well seal \_\_\_\_\_  
How was cement grout placed? pressure grout  
Was pump installed? \_\_\_\_\_ Type \_\_\_\_\_ HP \_\_\_\_\_ Depth \_\_\_\_\_ ft.  
Was a drive shoe used?  Yes  No Flange \_\_\_\_\_ Size: location \_\_\_\_\_ ft.  
Did any strata contain unusable water?  Yes  No  
Type of Water? \_\_\_\_\_ depth of strata \_\_\_\_\_  
Method of sealing strata off \_\_\_\_\_  
Was well gravel packed?  Yes  No Size of gravel: \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(10) LOCATION OF WELL:  
County Lane Driller's well number \_\_\_\_\_  
" Section 14 T. 18 R. 4W W.M.  
Tax Lot # 03800 Lot \_\_\_\_\_ Blk. \_\_\_\_\_ Sub-division \_\_\_\_\_  
Address at well location: \_\_\_\_\_

(11) WATER LEVEL: Completed well.  
Depth at which water was first found 45 ft.  
Static level 50 ft. below land surface. Date 8-25-80  
Artesian pressure \_\_\_\_\_ lbs. per square inch. Date \_\_\_\_\_

(12) WELL LOG: Diameter of well below casing 6"  
Depth drilled 400 ft. Depth of completed well 400 ft.  
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Soil	0	3	
Clay & Boulders	3	15	
Basalt Somalimes	15	115	
Broken Red Junk	115	118	
Blue Grey Sandstone	118	220	50
Dark Grey Sandstone	220	335	50
Light Grey Sandstone	335	400	

Work started 8-22 19 80 Completed 8-25 19 80  
Date well drilling machine moved off of well 8-25 19 80

Drilling Machine Operator's Certification:  
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.  
(Signed) Carl Pletcher Date 9-13 19 80  
Drilling Machine Operator

Drilling Machine Operator's License No. 386  
Water Well Contractor's Certification:  
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  
Name Fitcher Pump & Drilling Co. (Type or print)  
(Person, firm or corporation)  
Address 87829 Green Hill Rd. Eugene, Ore. 97402  
(Signed) Carl Pletcher (Water Well Contractor)  
Contractor's License No. 104 Date 9-13 1980

NOTICE TO WATER WELL CONTRACTOR  
The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT,  
HALEM, OREGON 97510  
within 30 days from the date of well completion. SP12650-830



NOTICE TO WATER WELL CONTRACTOR  
The original and first copy  
of this report are to be  
filed with the  
STATE ENGINEER, SALEM, OREGON 97310  
within 30 days from the date  
of well completion.

RECEIVED  
WATER WELL REPORT  
STATE OF OREGON OCT 27 1972  
(Please type or print)  
STATE ENGINEER  
SALEM, OREGON

18S/4W-14  
LANE 17031

(1) OWNER:  
Name Edward Weber  
Address Rt 3 Box 185  
Ugoune, Oregon

(2) TYPE OF WORK (check):  
New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 11.

(3) TYPE OF WELL: (4) PROPOSED USE (check):  
Rotary  Driven  Domestic  Industrial  Municipal   
Cable  Jetted  Irrigation  Test Well  Other   
Dug  Bored

(5) CASING INSTALLED:  
6" Diam. from 0 ft. to 20 ft. Gage # 250  
Threaded  Welded

(6) PERFORATIONS:  
Type of perforator used \_\_\_\_\_  
Size of perforations in. by in.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(7) SCREENS:  
Well screen installed?  Yes  No  
Manufacturer's Name \_\_\_\_\_  
Type \_\_\_\_\_ Model No. \_\_\_\_\_  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(8) WELL TESTS:  
Drawdown is amount water level is lowered below static level  
Was a pump test made?  Yes  No If yes, by whom? \_\_\_\_\_  
Yield: \_\_\_\_\_ gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
tested with air; estimate could fluctuate  
slug test 8 gal./min with 114 ft. drawdown after 1 hrs.  
Artesian flow \_\_\_\_\_ g.p.m.  
Temperature of water \_\_\_\_\_ Depth artesian flow encountered \_\_\_\_\_ ft.

(9) CONSTRUCTION:  
Well seal—Material used Cement grout  
Well sealed from land surface to 30 19 ft.  
Diameter of well bore to bottom of seal 10 in.  
Diameter of well bore below seal 6 in.  
Number of sacks of cement used in well seal 10 sacks  
Number of sacks of bentonite used in well seal \_\_\_\_\_ sacks  
Brand name of bentonite \_\_\_\_\_  
Number of pounds of bentonite per 100 gallons of water \_\_\_\_\_ lbs./100 gals.  
Was a drive shoe used?  Yes  No Plug \_\_\_\_\_ Size; location \_\_\_\_\_ ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? \_\_\_\_\_ depth of strata \_\_\_\_\_  
Method of sealing strata off \_\_\_\_\_  
Was well gravel packed?  Yes  No Size of gravel: \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(10) LOCATION OF WELL:  
County II Lane Driller's well number \_\_\_\_\_  
Section 14 T. 18S R. 4W W.M.  
Bearing and distance from section or subdivision corner \_\_\_\_\_

(11) WATER LEVEL: Completed well.  
Depth at which water was first found 72 ft.  
Static level 13 ft. below land surface. Date 10-13-72  
Artesian pressure \_\_\_\_\_ lbs. per square inch. Date \_\_\_\_\_

(12) WELL LOG: Diameter of well below casing 6"  
Depth drilled 127 ft. Depth of completed well 127 ft.  
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
top soil	0'	1'	
brown clay	1	5	
brown clay & boulders	5	13	
black gasalt	13	72	
blue claystone	72	86	
blue gray sandstone	86	112	
gray shales & white cong	112	115	
gray claystone	115	127	

Work started 10-12-72 19 \_\_\_\_\_ Completed 10-13-72 19 \_\_\_\_\_  
Date well drilling machine moved off of well 10-14-72 19 \_\_\_\_\_

Drilling Machine Operator's Certification:  
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.  
[Signed] Cassey L. Jones Date 10-23-72  
(Drilling Machine Operator)  
Drilling Machine Operator's License No. 521

Water Well Contractor's Certification:  
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  
Name CASEY JONES WELL DRILLING CO INC  
(Person, firm or corporation) (Type or print)  
Address Rt. 8 Box 695 Pleasant Hill, Ore  
[Signed] Cassey L. Jones  
(Water Well Contractor)  
Contractor's License No. 559 Date 10-23-72 19 \_\_\_\_\_

**RECEIVED**  
JUN 10 1966

NOTICE TO WATER WELL CONTRACTOR  
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON, within 30 days from the date of well completion.

**STATE ENGINEER**  
STATE OF OREGON  
(Please type or print)

State Well No. 18/4w-14  
State Permit No. LANE 17032

(1) OWNER:  
Name Norman O & Elaine M. Heaton  
Address Milwaukie, Oregon

(2) LOCATION OF WELL:  
County Lane Driller's well number \_\_\_\_\_  
1/4 Section 14 T. 18N R. 4 West W.M.  
Bearing and distance from section or subdivision corner  
Beginning Southwesterly right of way of Brown Hwy. 1.51 mi. N. from North-South section line Sect. 14 - T. 18N. R. 4 West of W.M. a tie line. West along Southwesterly right-of-way 4670 ft. thence South to S. line of North Bank of Milwaukie S.W. 1/4 E. on S.W. 1/4

(3) TYPE OF WORK (check):  
New Well  Deepening  Reconditioning  Abandon   
Randomness, describe material and procedure in Item 12.

(4) PROPOSED USE (check):  
Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

(5) TYPE OF WELL:  
Rotary  Driven   
Cable  Jetted   
Dug  Bored

(6) CASING INSTALLED:  
Threaded  Welded   
6 " Diam. from 0 ft. to 30 ft. Gage by well  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_

(7) PERFORATIONS:  
Perforated?  Yes  No  
Type of perforator used \_\_\_\_\_  
Size of perforations in. by in.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(8) SCREENS:  
Well screen installed?  Yes  No  
Manufacturer's Name \_\_\_\_\_  
Type \_\_\_\_\_ Model No. \_\_\_\_\_  
In. Elot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Diam. \_\_\_\_\_ Elot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(9) CONSTRUCTION:  
Well seal - Material used in seal Pentontite Slurry  
Depth of seal 8.0 ft. Was a packer used? NO  
Diameter of well bore to bottom of seal 10 in.  
Were any loose strata cemented off?  Yes  No Depth \_\_\_\_\_  
Was a drive shoe used?  Yes  No  
Was well gravel packed?  Yes  No Size of gravel: \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? \_\_\_\_\_ depth of strata \_\_\_\_\_  
Method of sealing strata off \_\_\_\_\_

(10) WATER LEVELS:  
Static level 7 1/2 ft. below land surface Date May 5 66  
Artesian pressure \_\_\_\_\_ lbs. per square inch Date \_\_\_\_\_

(11) WELL TESTS:  
Drawdown is amount water level is lowered below static level.  
Was a pump test made?  Yes  No If yes, by whom? Myself  
Yield: 8 gal./min. with 50 ft. drawdown after 4 hrs.  
Bailer test 10 gal./min. with 65 ft. drawdown after 2 hrs.  
Artesian flow \_\_\_\_\_ g.p.m. Date \_\_\_\_\_  
Temperature of water \_\_\_\_\_ Was a chemical analysis made?  Yes  No

(12) WELL LOG:  
Diameter of well below casing 4 inch  
Depth drilled 125 ft. Depth of completed well 120 ft.  
Formation: Describes by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Clay - Brown & bl. irregular	0	12.00
Basaltes - Clay Red	12	15
Hard rock - Dark in color	16	20
Hard rock - Dark in color	20	26
Hard rock - Dark in color	26	31
Hard Rock - Dark with light brown color showing in Bailer tests	31	40
Hard Rock - Dark in color	40	50
Hard Rock - Dark with blue shale showing in Bailer tests	50	65
Hard Rock - Dark	65	75
Hard Rock - Dark	75	83
Hard Rock - Dark - occasional red showing up in Bailer test	83	95
Hard Rock - Dark	95	115
Hard Rock - Dark with a blue & green color showing in Bailer tests	115	124
Broken fragments of sand	124	125
Crisis in fault of igneous rocks showing up in Bailer tests		

Work started Apr 18 1966 Completed May 5 1966  
Date well drilling machine moved off of well May 5 1966

(13) PUMP:  
Manufacturer's Name Zage Bank - Morse  
Type: Injection Pump H.P. 1/2

Water Well Contractor's Certification:  
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  
NAME C.E. Gardiner & Son  
(Person, firm or corporation) (Type or print)  
Address 1941 Haxxis St. Eugene, Ore  
Drilling Machine Operator's License No. 265 265  
[Signed] Raymond S. Gardiner  
(Water Well Contractor)  
Contractor's License No. 295 Date May 9 1966

(USE ADDITIONAL SHEETS IF NECESSARY)









NOTICE TO WATER WELL CONTRACTOR  
The original and first copy  
of this report are to be  
filed with the  
STATE ENGINEER, SALEM, OREGON 97310  
within 90 days from the date  
of well completion.

WATER WELL REPORT

STATE OF OREGON  
(Please type or print)

(Do not write above this line)

RECEIVED

AUG 16 1976

WATER RESOURCES DEPT.

State Well No.

State Permit No.

LANE 17036

18S/4W-74

(1) OWNER:

Name Wayne Weber  
Address 2480 Panorama Drive, Eugene, Oregon

(2) TYPE OF WORK (check):

New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 11.

(3) TYPE OF WELL:

Rotary  Driven   
Cable  Jetted   
 Bored

(4) PROPOSED USE (check):

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

(5) CASING INSTALLED:

Threaded  Welded   
6 ID Diam. from Plus 1 ft. to -39 ft. Gage .025  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_

(6) PERFORATIONS:

Perforated?  Yes  No.  
Type of perforator used \_\_\_\_\_  
Size of perforations \_\_\_\_\_ in. by \_\_\_\_\_ in.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(7) SCREENS:

Well screen installed?  Yes  No  
Manufacturer's Name \_\_\_\_\_ Model No. \_\_\_\_\_  
Type \_\_\_\_\_ Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level  
Was a pump test made?  Yes  No If yes, by whom?  
Pump: \_\_\_\_\_ gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
Air Well output may fluctuate  
Pump test 1 1/2 gal./min. with MAX ft. drawdown after 6 hrs.  
Artesian flow \_\_\_\_\_ g.p.m.  
Temperature of water \_\_\_\_\_ Depth artesian flow encountered \_\_\_\_\_ ft.

(9) CONSTRUCTION:

Well seal—Material used Cement  
Well sealed from land surface to 39 ft.  
Diameter of well bore to bottom of seal 10 in.  
Diameter of well bore below seal 6 in.  
Number of sacks of cement used in well seal 16 sacks  
Number of sacks of bentonite used in well seal \_\_\_\_\_ sacks  
Brand name of bentonite \_\_\_\_\_  
Number of pounds of bentonite per 100 gallons of water \_\_\_\_\_ lbs./100 gals.  
Was a drive shoe used?  Yes  No Flings \_\_\_\_\_ Size: location \_\_\_\_\_ ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? \_\_\_\_\_ depth of strata \_\_\_\_\_  
Method of sealing strata off \_\_\_\_\_  
Was well gravel packed?  Yes  No Size of gravel: \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(10) LOCATION OF WELL:

County Lane Driller's well number 7635  
\_\_\_\_\_ Section 14 T. 18 S. R. 4W W.M.  
Bearing and distance from section or subdivision corner \_\_\_\_\_

(11) WATER LEVEL: Completed well.

Depth at which water was first found 185 ft.  
Static level 90 ft. below land surface. Date 6-17-76  
Artesian pressure \_\_\_\_\_ lbs. per square inch. Date \_\_\_\_\_

(12) WELL LOG:

Diameter of well below casing 6  
Depth drilled 425 ft. Depth of completed well 425 ft.  
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Topsoil	0	2	
Basalt Boulders & Clay	2	33	
Basalt	33	130	
Soft (Lt) Green Tuff SS	130	132	
Basalt	132	185	
Blue Tuff SS	185	231	
Red Brown Tuff SS	231	262	
Blue Gray Tuff SS	262	356	
Soft Blue Gray Tuff SS	356	425	

Work started 6-14 1976 Completed 6-17 1976  
Date well drilling machine moved off of well 6-17 1976

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.  
[Signed] Paul Christensen Date 6-17, 1976.  
(Drilling Machine Operator)  
Drilling Machine Operator's License No. 612

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  
Name Mark Christensen, Christensen Drilling  
(Person, firm or corporation) (Type or print)  
Address 33132 Coleman Road, Eugene, Oregon 97401  
[Signed] Mark Christensen  
(Water Well Contractor)  
Contractor's License No. 91 Date 6-17, 1976

NOTICE TO WATER WELL CONTRACTOR  
 The original and first copy  
 of this report are to be  
 filed with the  
 STATE ENGINEER, SALEM, OREGON 97310  
 within 30 days from the date  
 of well completion.

WATER WELL REPORT

STATE OF OREGON  
 (Please type or print)

(Do not write above this line)

RECEIVED  
 AUG. 10 1976  
 State Well No. LANE 17037  
 State Permit No. 185/4W-14

(1) OWNER:  
 Name Wayne Weber  
 Address 2480 Panorama Drive, Eugene, Oregon

(2) TYPE OF WORK (check):  
 New Well  Deepening  Reconditioning  Abandon   
 If abandonment, describe material and procedure in Item 11.

(3) TYPE OF WELL: (4) PROPOSED USE (check):  
 Rotary  Driven  Domestic  Industrial  Municipal   
 Cable  Jetted  Irrigation  Test Well  Other   
 Auger  Bored

(5) CASING INSTALLED: Threaded  Welded   
6 ID- Diam. from Plus 1 ft. to 3 1/4 ft. Gage .025  
 " Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_  
 " Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_

(6) PERFORATIONS: Perforated?  Yes  No.  
 Type of perforator used \_\_\_\_\_  
 Size of perforations in. by in.  
 \_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
 \_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
 \_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(7) SCREENS: Well screen installed?  Yes  No  
 Manufacturer's Name \_\_\_\_\_ Model No. \_\_\_\_\_  
 Type \_\_\_\_\_  
 Diam. Slot size Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
 Diam. Slot size Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level  
 Was a pump test made?  Yes  No If yes, by whom?  
 Fluid: \_\_\_\_\_ gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
 Air \_\_\_\_\_  
 Water test 0 gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
 Artesian flow \_\_\_\_\_ g.p.m.  
 Temperature of water \_\_\_\_\_ Depth artesian flow encountered \_\_\_\_\_ ft.

(9) CONSTRUCTION:  
 Well seal—Material used CEMENT GROUT  
 Well sealed from land surface to 3 1/4 ft.  
 Diameter of well bore to bottom of seal 10 in.  
 Diameter of well bore below seal 6 in.  
 Number of sacks of cement used in well seal 2 sacks  
 Number of sacks of bentonite used in well seal \_\_\_\_\_ sacks  
 Brand name of bentonite \_\_\_\_\_  
 Number of pounds of bentonite per 100 gallons of water \_\_\_\_\_ lbs./100 gals.  
 Was a drive shoe used?  Yes  No Flugs \_\_\_\_\_ Size: location \_\_\_\_\_ ft.  
 Did any strata contain unusable water?  Yes  No  
 Type of water? \_\_\_\_\_ depth of strata \_\_\_\_\_  
 Method of sealing strata off \_\_\_\_\_  
 Was well gravel packed?  Yes  No Size of gravel: \_\_\_\_\_  
 Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(10) LOCATION OF WELL:  
 County Lane Section 14 T. 18S R. 4W W.M. \_\_\_\_\_  
 Bearing and distance from section or subdivision corner \_\_\_\_\_

(11) WATER LEVEL: Completed well.  
 Depth at which water was first found 210 ft.  
 Static level 210 ft. below land surface. Date 6-21-76  
 Artesian pressure \_\_\_\_\_ lbs. per square inch. Date \_\_\_\_\_

(12) WELL LOG: Diameter of well below casing 6  
 Depth drilled 270 ft. Depth of completed well 270 ft.  
 Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Topsoil	0	2	
Clay	2	15	
Weathered SS	15	28	
Basalt	28	205	
Soft Red Tuff SS	205	210	
Dacey Red Tuff SS	210	230	
Fault Gouge (Red Tuff ss/ Basalt mix)	230	270	
Basalt	270		

Work started 6-17- 19 76 Completed 6-21 19 76  
 Date well drilling machine moved off of well 6-21 19 76

Drilling Machine Operator's Certification:  
 This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.  
 [Signed] Paul Christensen Date 6-21, 19 76  
 (Drilling Machine Operator)  
 Drilling Machine Operator's License No. 612

Water Well Contractor's Certification:  
 This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  
 Name Mark Christensen, Christensen Drilling  
 (Person, firm or corporation) (Type or print)  
 Address 33132 Coleman Rd. Eugene, Oregon 97401  
 [Signed] Mark Christensen  
 (Water Well Contractor)  
 Contractor's License No. 27 Date 6-21- 19 76













NOTICE TO WATER WELL CONTRACTOR: The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

**RECEIVED**  
AUG 2 1975  
STATE OF OREGON  
WATER RESOURCES DEPT.  
SALEM, OREGON

WATER WELL REPORT  
(Please type or print)  
(Do not write above this line)

State Well No. 185/4w-14  
State Permit No. LANE 17044

**(1) OWNER:**  
Name Jesse Ulloa  
Address 74 Mary Lane Eugene, Oregon 97405

**(2) TYPE OF WORK (check):**  
New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 11.

**(3) TYPE OF WELL:** Rotary  Driven   
Cable  Jetted   
Dug  Bored

**(4) PROPOSED USE (check):** Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

**CASING INSTALLED:** Threaded  Welded   
6" Diam. from 0 ft. to 60 ft. Gage 250  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_

**PERFORATIONS:** Perforated?  Yes  No.  
Type of perforator used \_\_\_\_\_  
Size of perforations in. by \_\_\_\_\_ in.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

**(7) SCREENS:** Well screen installed?  Yes  No  
Manufacturer's Name \_\_\_\_\_  
Type \_\_\_\_\_ Model No. \_\_\_\_\_  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

**(8) WELL TESTS:** Drawdown is amount water level is lowered below static level.  
Was a pump test made?  Yes  No If yes, by whom? \_\_\_\_\_  
Yield: \_\_\_\_\_ gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
Tested by Air \_\_\_\_\_  
Resistance 7 1/2 gal./min. with 102 ft. drawdown after 1 hr.  
Artesian flow \_\_\_\_\_ g.p.m.  
Temperature of water \_\_\_\_\_ Depth artesian flow encountered \_\_\_\_\_ ft.

**(9) CONSTRUCTION:**  
Well seal—Material used Cement  
Well sealed from land surface to 39 ft.  
Diameter of well bore to bottom of seal 10 in.  
Diameter of well bore below seal 6 in.  
Number of sacks of cement used in well seal 7 sacks  
Number of sacks of bentonite used in well seal \_\_\_\_\_ sacks  
Brand name of bentonite \_\_\_\_\_  
Number of pounds of bentonite per 100 gallons of water \_\_\_\_\_ lbs./100 gals.  
Was a drive shoe used?  Yes  No Flugs \_\_\_\_\_ Size: location \_\_\_\_\_ ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? \_\_\_\_\_ depth of strata \_\_\_\_\_  
Method of sealing strata off \_\_\_\_\_  
Was well gravel packed?  Yes  No Size of gravel: \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

**(10) LOCATION OF WELL:**  
County Lane Driller's well number \_\_\_\_\_  
" Section 14 T. 18S R. 4W W.M. \_\_\_\_\_  
Bearing and distance from section or subdivision corner \_\_\_\_\_

**(11) WATER LEVEL: Completed well.**  
Depth at which water was first found 104 ft.  
Static level 48 ft. below land surface. Date 7/29/75  
Artesian pressure \_\_\_\_\_ lbs. per square inch. Date \_\_\_\_\_

**(12) WELL LOG:** Diameter of well below casing 6"  
Depth drilled 150 ft. Depth of completed well 150 ft.  
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report such changes in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Top Soil	0	1	
Clay & Boulders	1	31	
Brown Claystone	31	33	
Gray Claystone	33	41	
Red Claystone	41	51	
Brown Claystone	51	58	
Gray Claystone	58	85	
Blue Gray Claystone	85	112	
Gray Claystone	112	150	

Work started 7/28/75 19 \_\_\_\_\_ Completed 7/29/75 19 \_\_\_\_\_  
Date well drilling machine moved off of well 7/29/75 19 \_\_\_\_\_

**Drilling Machine Operator's Certification:**  
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.  
[Signed] A. K. Jones Date 7/29/75 19 \_\_\_\_\_  
(Drilling Machine Operator)  
Drilling Machine Operator's License No. 702

**Water Well Contractor's Certification:**  
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  
Name Cassy Jones Well Drilling Co., Inc.  
(Person, firm or corporation) (Type or print)  
Address 7115 Immigrant Rd. Pleasant Hill, Oregon  
[Signed] Bill Leonard  
(Water Well Contractor)  
Contractor's License No. 559 Date 7/29/75 19 \_\_\_\_\_

NOTICE TO WATER WELL CONTRACTOR  
The original and first copy of this report  
are to be filed with:

WATER RESOURCES DEPARTMENT  
SALEM, OREGON 97310  
within 30 days from the date  
of well completion.

**RECEIVED**

**WATER WELL REPORT**

STATE OF OREGON  
(Please type or print)

NOV 16 1978

(Do not write above this line)

State Well No. 183/4w-14a  
State Permit No. LANE 17045

WATER RESOURCES DEPT.

**(1) OWNER:** SALEM, OREGON  
Name Doug Pawley  
Address 2050 Irwin Way  
Eugene, Oregon 97402

**(2) TYPE OF WORK (check):**  
New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 12.

**(3) TYPE OF WELL:** Rotary  Driven   
Cable  Jetted   
Dig  Bored   
**(4) PROPOSED USE (check):** Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

**CASING INSTALLED:** Threaded  Welded   
6 " Diam. from 1 ft. to 39 ft. Gage .250  
0.5 " Diam. from 21 ft. to 201 ft. Gage 10  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_

**(5) PERFORATIONS:** Perforated?  Yes  No.  
(In Liner Only)  
Type of perforator used Torch  
Size of perforations 4 in. by 1/2 in.  
33 perforations from 181 ft. to 201 ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

**(7) SCREENS:** Well screen installed?  Yes  No  
Manufacturer's Name \_\_\_\_\_  
Type \_\_\_\_\_ Model No. \_\_\_\_\_  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

**(8) WELL TESTS:** Drawdown is amount water level is lowered below static level.  
**AIR**  
Was a pump test made?  Yes  No. If yes, by whom? Driller  
Yield: 16 gal./min. with 150 ft. drawdown after Driller  
\_\_\_\_\_ gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_  
\_\_\_\_\_ gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_  
Buffer test NO gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
Artesian flow \_\_\_\_\_ g.p.m.  
Temperature of water 54 ° Depth artesian flow encountered \_\_\_\_\_ ft.

**(9) CONSTRUCTION:** Well seal—Material used Portland Cement Type III  
Well sealed from land surface to 39 ft.  
Diameter of well bore to bottom of seal 10 in.  
Diameter of well bore below seal 6 in.  
Number of sacks of cement used in well seal 10 sacks  
How was cement grout placed? Poured From Top

Was a drive shoe used?  Yes  No. Plugs \_\_\_\_\_ Size: location \_\_\_\_\_ ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? \_\_\_\_\_ depth of strata \_\_\_\_\_  
Method of sealing strata off \_\_\_\_\_  
Was well gravel packed?  Yes  No. Size of gravel: \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

**(10) LOCATION OF WELL:** County Lane Driller's well number 1431 -CP670  
NE 1/4 Section 14 T. 18 R. 4W W.M. \_\_\_\_\_  
Bearing and distance from section or subdivision corner \_\_\_\_\_

**(11) WATER LEVEL: Completed well.**  
Depth at which water was first found 191 ft.  
Static level 41 ft. below land surface. Date 10/25/78  
Artesian pressure \_\_\_\_\_ lbs. per square inch. Date \_\_\_\_\_

**(12) WELL LOG:** Diameter of well below casing 6"  
Depth drilled 201 ft. Depth of completed well 201 ft.  
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Top Soil	0	5	
Brown Silt & Clay	5	13	
Hard Grey Rock	13	31	
Blue Shale	31	87	
Brown Shale - Soft	87	158	
Blue Shale	158	201	41

Work started 10/24/ 1978 Completed 10/25/ 1978  
Date well drilling machine moved off of well 10/26/ 1978

**Drilling Machine Operator's Certification:**  
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.  
[Signed] Arthur L. Swain Date 10/26/ 78  
(Drilling Machine Operator)

Drilling Machine Operator's License No. 717

**Water Well Contractor's Certification:**  
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  
Name Carter's Drilling & Pump Service  
(Person, firm or corporation) (Type or print)  
Address P.O. Box 46-Springfield, Ore 97477  
[Signed] James J. Carter  
(Water Well Contractor)  
Contractor's License No. 126 Date 10/26/ 1978

(USE ADDITIONAL SHEETS IF NECESSARY)

SP-10004-110

NOTICE TO WATER WELL CONTRACTOR  
The original and first copy  
of this report are to be  
filed with the

STATE ENGINEER, SALEM, OREGON 97310  
within 30 days from the date  
of well completion.

WATER WELL REPORT

STATE OF OREGON SEP 6 1973 State Well No. 185/4W-14  
(Please type or print) STATE ENGINEER State Permit No. LANE 17046  
(Do not write above this line) SALEM, OREGON

RECEIVED

ab

(1) OWNER:

Name Robert Schafer  
Address 2140 Rocky Lane  
Eugene, Oregon 97401

(2) TYPE OF WORK (check):

New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary  Driven   
Cable  Rotted   
Dug  Bored

(4) PROPOSED USE (check):

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

(5) CASING INSTALLED:

Threaded  Welded   
6" Diam. from 0 ft. to 60 ft. Gage 250  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_

(6) PERFORATIONS:

Perforated?  Yes  No  
Type of perforator used \_\_\_\_\_  
Size of perforations in. by in. \_\_\_\_\_  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(7) SCREENS:

Well screen installed?  Yes  No  
Manufacturer's Name \_\_\_\_\_  
Type \_\_\_\_\_ Model No. \_\_\_\_\_  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level  
Was a pump test made?  Yes  No If yes, by whom?  
Yield: \_\_\_\_\_ gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
Baller test 35 gal./min. with 50 ft. drawdown after 2 hrs.  
Artesian flow \_\_\_\_\_ g.p.m.  
Temperature of water 52 Depth artesian flow encountered \_\_\_\_\_ ft.

(9) CONSTRUCTION:

Well seal—Material used BENTONITE  
Well sealed from land surface to 20 ft.  
Diameter of well bore to bottom of seal 10 in.  
Diameter of well bore below seal 6 in.  
Number of sacks of cement used in well seal \_\_\_\_\_ sacks  
Number of sacks of bentonite used in well seal 2 sacks  
Brand name of bentonite YELLOW STONE  
Number of pounds of bentonite per 100 gallons of water 133 lbs./100 gals.  
Was a drive shoe used?  Yes  No Flugs \_\_\_\_\_ Size: location \_\_\_\_\_ ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? \_\_\_\_\_ depth of strata \_\_\_\_\_  
Method of sealing strata off \_\_\_\_\_  
Was well gravel packed?  Yes  No Size of gravel: \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(10) LOCATION OF WELL:

County Lane Driller's well number 359  
NW  $\frac{1}{4}$  NE  $\frac{1}{4}$  Section 14 T. 18S R. 4W W.M.  
Bearing and distance from section or subdivision corner \_\_\_\_\_

(11) WATER LEVEL: Completed well.

Depth at which water was first found 60 ft.  
Static level 18 ft. below land surface. Date 8/29/73  
Artesian pressure \_\_\_\_\_ lbs. per square inch. Date \_\_\_\_\_

(12) WELL LOG:

Diameter of well below casing 6"  
Depth drilled 88 ft. Depth of completed well 88 ft.  
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
SOIL	0	1	
BROWN CLAY & SAND	1	28	
BROWN CLAY	28	50	
GRAY CLAYSTONE	50	65	28
LIGHT GRAY SANDSTONE	65	80	24
TAN ROCK	80	88	18

Work started 8/23 1973 Completed 8/29 1973  
Date well drilling machine moved off of well 8/29 1973

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.  
[Signed] Thom R. B. Jones Date 8/29 1973  
Drilling Machine Operator

Drilling Machine Operator's License No. 747

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name Miller-Jensen Company  
(Person, firm or corporation) (Type or print)  
Address P O Box 2571 Eugene, Or 97402  
[Signed] Arvid Miller Owner  
(Water Well Contractor)

Contractor's License No. 179 Date 8-30-73 19

(USE ADDITIONAL SHEETS IF NECESSARY)

SP-1546-119



**NOTICE TO WATER WELL CONTRACTOR**  
The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310  
within 30 days from the date of well completion.

**WATER WELL REPORT**

**RECEIVED**

STATE OF OREGON  
(Please type or print)

AUG 28 1974

State Well No.

185/4W-14dd

STATE ENGINEER  
SALEM, OREGON

State Permit No.

LANE 17048

(1) OWNER:  
Name ERNEST MUSTER  
Address RR3 BOX 171  
EUGENE ORE

(10) LOCATION OF WELL: LANE HWY  
County LANE Driller's well number BLANTON HEIGHTS  
SE 1/4 SE 1/4 Section 14 T.18 S. R. 4W W.M.  
Bearing and distance from section or subdivision corner

(2) TYPE OF WORK (check):  
New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in item 12.

(11) WATER LEVEL: Completed well.  
Depth at which water was first found 90 ft.  
Static level 15 ft. below land surface. Date 8/17/74  
Artesian pressure \_\_\_\_\_ lbs. per square inch. Date \_\_\_\_\_

(3) TYPE OF WELL: Rotary  Driven   
Cable  Jetted   
Dug  Bored   
(4) PROPOSED USE (check): Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

(12) WELL LOG: Diameter of well below casing 6  
Depth drilled 340 ft. Depth of completed well 340 ft.  
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

CASING INSTALLED: Threaded  Welded   
\_\_\_\_\_ " Diam. from \_\_\_\_\_ ft. to 26 ft. Gage 250  
\_\_\_\_\_ " Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_  
\_\_\_\_\_ " Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_

MATERIAL	From	To	SWL
TOP SOIL	0	2	
Red clay	20	20	
Red Rock	20	95	15
Basalt	95	180	15
Grey Rock	180	240	15
Red Shell	240	260	15
Grey Rock	260	340	15

PERFORATIONS: Perforated?  Yes  No.  
Type of perforator used \_\_\_\_\_  
Size of perforations in. by in.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(7) SCREENS: Well screen installed?  Yes  No  
Manufacturer's Name \_\_\_\_\_  
Type \_\_\_\_\_ Model No. \_\_\_\_\_  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level.  
Was a pump test made?  Yes  No If yes, by whom?  
Yield: \_\_\_\_\_ gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
Show  
Water test 2 gal./min. with 325 ft. drawdown after 1 hrs.  
Artesian flow \_\_\_\_\_ g.p.m.  
Temperature of water \_\_\_\_\_ Depth artesian flow encountered \_\_\_\_\_ ft.

(9) CONSTRUCTION: Well seal—Material used CEMENT  
Well sealed from land surface to 26 ft.  
Diameter of well bore to bottom of seal 10 in.  
Diameter of well bore below seal 6 in.  
Number of sacks of cement used in well seal 4 sacks  
Number of sacks of bentonite used in well seal \_\_\_\_\_ sacks  
Brand name of bentonite \_\_\_\_\_  
Number of pounds of bentonite per 100 gallons of water \_\_\_\_\_ lbs./100 gals.  
Was a drive shoe used?  Yes  No Flugs \_\_\_\_\_ Size: location \_\_\_\_\_ ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? \_\_\_\_\_ depth of strata \_\_\_\_\_  
Method of sealing strata off \_\_\_\_\_  
Was well gravel packed?  Yes  No Size of gravel: \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

Work started 9/26 1974 Completed 9/30 1974  
Date well drilling machine moved off of well 9/30 1974

Drilling Machine Operator's Certification:  
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.  
[Signed] Frank Wilson Date 8/17, 1974  
(Drilling Machine Operator)

Drilling Machine Operator's License No. \_\_\_\_\_

Water Well Contractor's Certification:  
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  
Name W.W. DRILLING  
(Person, firm or corporation) (Type or print)  
Address 2320 MAIN SPRINGFIELD ORE  
[Signed] Frank Wilson  
(Water Well Contractor)  
Contractor's License No. 562 Date 8/7, 1974

**NOTICE TO WATER WELL CONTRACTOR**

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

**RECEIVED**

SEP 11 1967

STATE ENGINEER

**WATER WELL REPORT**

STATE OF OREGON

(Please type or print) (Do not write above this line)

State Well No. 19/4W-14 C

State Permit No. LANE/17049

**(1) OWNER:**

Name Dr. Charles S. Williams  
Address Lorane Highway  
Eugene, Oregon

**(2) TYPE OF WORK (check):**

New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in item 12.

**(3) TYPE OF WELL:**

Rotary  Driven  Cable  Jetted  Dug  Bored   
Domestic  Industrial  Municipal  Irrigation  Test Well  Other

**(4) PROPOSED USE (check):**

**CASING INSTALLED:**

Threaded  Welded   
5" Diam. from 0 ft. to 157 ft. Gage 14.81  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_

**PERFORATIONS:**

Type of perforator used torch Perforated?  Yes  No  
Size of perforations 1/4 in. by 4 in.  
10 perforations from 50 ft. to 55 ft.  
10 perforations from 60 ft. to 75 ft.  
10 perforations from 80 ft. to 85 ft.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

**(7) SCREENS:**

Well screen installed?  Yes  No  
Manufacturer's Name \_\_\_\_\_ Type \_\_\_\_\_ Model No. \_\_\_\_\_  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

**(8) WATER LEVEL: Completed well.**

Static level 17 ft. below land surface Date \_\_\_\_\_  
Pneumatic pressure \_\_\_\_\_ lbs. per square inch Date \_\_\_\_\_

**(9) WELL TESTS:**

Drawdown is amount water level is lowered below static level  
Was a pump test made?  Yes  No If yes, by whom? \_\_\_\_\_  
Yield: \_\_\_\_\_ gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.

Ball test 4 gal./min. with 280qt. drawdown after 1 hrs.

Artesian flow \_\_\_\_\_ g.p.m. Date \_\_\_\_\_

Temperature of water \_\_\_\_\_ Was a chemical analysis made?  Yes  No

**(10) CONSTRUCTION:**

Well seal—Material used \_\_\_\_\_  
Depth of seal \_\_\_\_\_ ft.  
Diameter of well bore to bottom of seal \_\_\_\_\_ in.  
Were any loose strata cemented off?  Yes  No Depth \_\_\_\_\_  
Was a drive shoe used?  Yes  No  
Did any strata contain unusable water?  Yes  No  
Type of water? \_\_\_\_\_ depth of strata \_\_\_\_\_  
Method of sealing strata off \_\_\_\_\_  
Was well gravel packed?  Yes  No Size of gravel: \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

**(11) LOCATION OF WELL:**

County Lane Driller's well number 111-A  
NE 1/4 NW 1/4 Section 14 T. 18S R. 12W W.M.  
Bearing and distance from section or subdivision corner \_\_\_\_\_

**(12) WELL LOG:**

Diameter of well below casing 6  
Depth drilled 300 ft. Depth of completed well 300 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
Black Basalt	50	85	
Red Clay stone (casing)	85	92	
Blue Claystone	92	130	
Black Basalt	130	160	
Blue-grey Sandstone	160	220	
Red Claystone	220	245	
Blue Sandstone	245	300	ft

Work started 8-2 1967 Completed 8-21 1967  
Date well drilling machine moved off of well \_\_\_\_\_ 19\_\_\_\_

**Drilling Machine Operator's Certification:**

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

(Signed) Walt Wilson Date 8-31 1967  
Drilling Machine Operator

**Drilling Machine Operator's License No. 69**

**Water Well Contractor's Certification:**

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Miller-Jensen Company  
(Person, firm or corporation) (Type or print)

Address P.O. Box 2751, Eugene, Oregon 97102

(Signed) Harold Miller Date \_\_\_\_\_ 19\_\_\_\_  
Water Well Contractor

Contractor's License No. 172 Date 9-1-67 19\_\_\_\_

















NOTICE TO WATER WELL CONTRACTOR  
The original and first copy  
of this report are to be  
filed with the  
STATE ENGINEER, SALEM, OREGON 97310  
within 30 days from the date  
of well completion.

**RECEIVED**  
WATER WELL REPORT

STATE OF OREGON MAY 9, 1976  
(Please type or print)

(Do not write above this line) RESOURCES DEPT.  
SALEM, OREGON

State Well No. 185/4W-15  
Field-Permit No. LAINE 17055

**(1) OWNER:**

Name John Horsfall  
Address 4765 Bailey Hill Road, Eugene, Oregon 97402

**(2) TYPE OF WORK (check):**

New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 12.

**(3) TYPE OF WELL:**

Rotary  Driven   
Cable  Jetted   
Pug  Bored

**(4) PROPOSED USE (check):**

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

**(5) CASING INSTALLED:**

6 " Diam. from Plus 1 ft. to 19 ft. Gage 250  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_

**PERFORATIONS:**

Perforated?  Yes  No  
Type of perforator used \_\_\_\_\_  
Size of perforations in. by \_\_\_\_\_ in.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

**(7) SCREENS:**

Well screen installed?  Yes  No  
Manufacturer's Name \_\_\_\_\_ Model No. \_\_\_\_\_  
Type \_\_\_\_\_  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

**(8) WELL TESTS:**

Drawdown is amount water level is lowered below static level  
Was a pump test made?  Yes  No If yes, by whom?  
Yield: \_\_\_\_\_ gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
Air Well output may fluctuate  
Blower test 10 1/2 gal./min. with Max ft. drawdown after 2 hrs.  
Artesian flow \_\_\_\_\_ g.p.m.  
Temperature of water \_\_\_\_\_ Depth artesian flow encountered \_\_\_\_\_ ft.

**(9) CONSTRUCTION:**

Well seal—Material used Cement  
Well sealed from land surface to 19 ft.  
Diameter of well bore to bottom of seal 10 in.  
Diameter of well bore below seal 6 in.  
Number of sacks of cement used in well seal 9 sacks  
Number of sacks of bentonite used in well seal \_\_\_\_\_ sacks  
Brand name of bentonite \_\_\_\_\_  
Number of pounds of bentonite per 100 gallons of water \_\_\_\_\_ lbs./100 gals.  
Was a drive shoe used?  Yes  No Pairs \_\_\_\_\_ Size: location \_\_\_\_\_ ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? \_\_\_\_\_ depth of strata \_\_\_\_\_  
Method of sealing strata off \_\_\_\_\_  
Was well gravel packed?  Yes  No Size of gravel: \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

**(10) LOCATION OF WELL:**

County Tang Driller's well number \_\_\_\_\_  
1/4 Section 15 T. 18S R. 4N W.M. \_\_\_\_\_  
Bearing and distance from section or subdivision corner \_\_\_\_\_

**(11) WATER LEVEL: Completed well.**

Depth at which water was first found 118 ft.  
Static level 118 ft. below land surface. Date 5-7-76  
Artesian pressure \_\_\_\_\_ lbs. per square inch. Date \_\_\_\_\_

**(12) WELL LOG:**

Diameter of well below casing 6 ft.  
Depth drilled 228 ft. Depth of completed well 228 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Clay and basalt boulders	0	12	
Basalt	12	118	
Gray Tuff	118	161	
Basalt	161	178	
Red Tuff	178	183	
Basalt	183	204	
Blue Gray Tuff Sandstone	204	228	

Work started 5/6 1976 Completed 5/7 1976  
Date well drilling machine moved off of well 5/7 1976

**Drilling Machine Operator's Certification:**

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Paul Christensen Date 5/7 1976  
(Drilling Machine Operator) 612

**Drilling Machine Operator's License No.**

**Water Well Contractor's Certification:**

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name Mark W. Christensen (Type or print)

Address 33132 Coleman Road, Eugene, Oregon 97401

[Signed] Mark Christensen (Water Well Contractor)

Contractor's License No. 97 Date 5/7 1976



NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON within 30 days from the date of well completion.

**RECEIVED**  
**JAN 28 1971**  
**STATE OF OREGON**  
**STATE ENGINEER**  
**SALEM, OREGON**

State Well No. 18/4W-15

State Permit No. LAINE 17056

(1) OWNER:

Name JOHN M. BIGGS  
 Address RR 3 Box 280  
CLATSOP COUNTY OREGON

(2) TYPE OF WORK (check):

New Well  Deepening  Reconditioning  Abandon

If abandonment, describe material and procedure in Item 13.

(3) TYPE OF WELL:

Rotary  Driven   
 Cable  Jetted   
 Dug  Bored

(4) PROPOSED USE (check):

Domestic  Industrial  Municipal   
 Irrigation  Test Well  Other

CASING INSTALLED:

Threaded  Welded   
6" Diam. from 6.6 ft. to 5.2 ft. Gage 250  
 " Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_  
 " Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_

PERFORATIONS:

Perforated?  Yes  No.  
 Types of perforator used \_\_\_\_\_  
 Size of perforations in. by \_\_\_\_\_ in.  
 \_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
 \_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
 \_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(7) SCREENS:

Well screen installed?  Yes  No  
 Manufacturer's Name \_\_\_\_\_  
 Type \_\_\_\_\_ Model No. \_\_\_\_\_  
 Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
 Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level.  
 Was a pump test made?  Yes  No. If yes, by whom?  
 Yield: \_\_\_\_\_ gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
Show  
 Pump test 12 gal./min. with 160 ft. drawdown after 1 hrs.  
 Artesian flow \_\_\_\_\_ g.p.m.  
 Temperature of water \_\_\_\_\_ Depth artesian flow encountered \_\_\_\_\_ ft.

(9) CONSTRUCTION:

Well seal—Material used Cement  
 Well sealed from land surface to \_\_\_\_\_ ft.  
 Diameter of well bore to bottom of seal 7.0 in.  
 Diameter of well bore below seal 6 in.  
 Number of sacks of cement used in well seal 5 sacks.  
 Number of sacks of bentonite used in well seal \_\_\_\_\_ sacks.  
 Brand name of bentonite \_\_\_\_\_  
 Number of pounds of bentonite per 100 gallons of water \_\_\_\_\_ lbs./100 gals.  
 Was a drive shoe used?  Yes  No. Flugs \_\_\_\_\_ Size: location \_\_\_\_\_ ft.  
 Did any strata contain unusable water?  Yes  No  
 Type of water? \_\_\_\_\_ depth of strata \_\_\_\_\_  
 Method of sealing strata off \_\_\_\_\_  
 Was well gravel packed?  Yes  No. Size of gravel: \_\_\_\_\_  
 Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(10) LOCATION OF WELL:

County LANE Driller's well number \_\_\_\_\_  
 1/4 Section 15 T. 18 S. R. 4 W. M.  
 Bearing and distance from section or subdivision corner \_\_\_\_\_

(11) WATER LEVEL: Completed well.

Depth at which water was first found 80 ft.  
 Static level 15 ft. below land surface. Date 1/6/71  
 Artesian pressure \_\_\_\_\_ lbs. per square inch. Date \_\_\_\_\_

(12) WELL LOG:

Diameter of well below casing 6"  
 Depth drilled 175 ft. Depth of completed well 175 ft.  
 Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report such change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
<u>Top Soil</u>	<u>0</u>	<u>8'</u>	
<u>Brown Clay</u>	<u>8'</u>	<u>28'</u>	
<u>Brown shale</u>	<u>28'</u>	<u>50'</u>	
<u>Blue Rock</u>	<u>50'</u>	<u>140'</u>	
<u>Brown shale</u>	<u>140'</u>	<u>145'</u>	
<u>Blue Rock</u>	<u>145'</u>	<u>175'</u>	<u>15'</u>

Work started 12/31/70 Completed 1/6/71  
 Date well drilling machine moved off of well 1/6/71

Drilling Machine Operator's Certification:  
 This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.  
 [Signed] Frank Wilson Date 1/14/71  
 (Drilling Machine Operator)  
 Drilling Machine Operator's License No. 404

Water Well Contractor's Certification:  
 This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  
 Name W. W. Drilling & Pump Ser  
 (Person, firm or corporation) (Type & print)  
 Address 2329 MAI-O-SPR-D-OR  
 [Signed] Walt W. Drilling  
 (Water Well Contractor)  
 Contractor's License No. 268 Date 1/21/71 1971











RECEIVED

DEC 17 1962 WATER WELL REPORT

NOTICE TO WATER WELL CONTRACTOR: The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

STATE OF OREGON (Please type or print)

State Well No. 18/4W-15 LANE 17069 State Permit No.

(1) OWNER: Name A. C. McDonald Address Lorane Rt. Box 285 Cottage Grove, Oregon

(2) LOCATION OF WELL: County Lane Driller's well number M 1/2 Section 215 T. 215 S. R. 2W W.M. Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check): New Well [ ] Deepening [x] Reconditioning [ ] Abandon [ ]

(4) PROPOSED USE (check): Domestic [x] Industrial [ ] Municipal [ ] Irrigation [ ] Test Well [ ] Other [ ]

(5) TYPE OF WELL: Rotary [ ] Driven [ ] Cable [x] Jetted [ ] Dug [ ] Bored [ ]

(6) CASING INSTALLED: Threaded [ ] Welded [ ] Diam. from ft. to ft. Gage

(7) PERFORATIONS: Perforated? [ ] Yes [ ] No Type of perforator used Size of perforations in. by in.

(8) SCREENS: Well screen installed [ ] Yes [x] No Manufacturer's Name Model No. Slot size Set from ft. to ft. Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION: Well seal—Material used in seal Depth of seal ft. Was a packer used? Diameter of well bore to bottom of seal in. Were any loose strata cemented off? [ ] Yes [x] No Depth Was a drive shoe used? [ ] Yes [x] No Was well gravel packed? [ ] Yes [x] No Size of gravel: Gravel placed from ft. to ft. Did any strata contain unusable water? [ ] Yes [x] No Type of water? Depth of strata Method of sealing strata off

(10) WATER LEVELS: Static level 55 ft. below land surface Date 11/10/62 Artesian pressure lbs. per square inch Date

(11) WELL TESTS: Drawdown is amount water level is lowered below static level Was a pump test made? [ ] Yes [x] No If yes, by whom? Yield: gal./min. with ft. drawdown after hrs. Bailor test 180 gal./min. with 42 ft. drawdown after 1 hrs. Artesian flow g.p.m. Date Temperature of water Was a chemical analysis made? [ ] Yes [x] No

(12) WELL LOG: Diameter of well below casing 5" Depth drilled 115 ft. Depth of completed well 200 ft. Formation: Describe by color, character, size of material and structure, and show thickness of silt/clay and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns: MATERIAL, FROM, TO. Rows: Clay, blue (85-125), Sandstone, gray (125-200)

Work started 1/3/62 IP Completed 11/10/62 19 Date well drilling machine moved off of well 11/10/62 19

(13) PUMP: Manufacturer's Name Type: H.P.

Water Well Contractor's Certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Casey Jones Well Drilling Co. (Person, firm or corporation) (Type or print) Address Rt. 2 Box 695, Creswell, Oregon

Drilling Machine Operator's License No. 155

(Signed) [Signature] (Water Well Contractor)

Contractor's License No. 108 Date 11/12/62 19









NOTICE TO WATER WELL CONTRACTOR  
The original and first copy of this report  
are to be filed with the

WATER RESOURCES DEPARTMENT.  
SALEM, OREGON 97310  
within 30 days from the date  
of well completion.

9 WATER WELL RECEIVED  
STATE OF OREGON

(Please type or print)  
NOV 29 1977  
(Do not write above this line)

State Well No. BS/4W-15dd  
State Permit No. LANE/17066

WATER RESOURCES DEPT.

(1) OWNER:

Name JACKIE Hill House  
Address 86093 LORANE Hwy  
EUGENE - ORE.

(2) TYPE OF WORK (check):

New Well  Deepening  Reconditioning  Abandon

If abandonment, describe material and procedure in Item 11.

(3) TYPE OF WELL:

Rotary  Driven   
Cable  Jetted   
Dug  Bored

(4) PROPOSED USE (check):

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

CASING INSTALLED:

Threaded  Welded   
6" Diam. from 0 ft. to 64 ft. Gage 250  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_

PERFORATIONS:

Perforated?  Yes  No  
Type of perforator used \_\_\_\_\_  
Size of perforations in. by \_\_\_\_\_ in.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(7) SCREENS:

Well screen installed?  Yes  No  
Manufacturer's Name \_\_\_\_\_  
Type \_\_\_\_\_ Model No. \_\_\_\_\_  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level  
Was a pump test made?  Yes  No If yes, by whom?  
Yield: \_\_\_\_\_ gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
Flow  
Ballor test 2 gal./min. with 200ft. drawdown after 1 hrs.  
Artesian flow \_\_\_\_\_ g.p.m.  
Temperature of water \_\_\_\_\_ Depth artesian flow encountered \_\_\_\_\_ ft.

(9) CONSTRUCTION:

Well seal—Material used Cement  
Well sealed from land surface to \_\_\_\_\_ ft.  
Diameter of well bore to bottom of seal 10 in.  
Diameter of well bore below seal 6 in.  
Number of sacks of cement used in well seal 10 sacks  
How was cement grout placed? Mixed & poured  
Was a drive shoe used?  Yes  No Plugs \_\_\_\_\_ Size: location \_\_\_\_\_ ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? \_\_\_\_\_ depth of strata \_\_\_\_\_  
Method of sealing strata off \_\_\_\_\_  
Was well gravel packed?  Yes  No Size of gravel: \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(10) LOCATION OF WELL:

County Lane Driller's well number \_\_\_\_\_  
SE 1/4 SE 1/4 Section 15, T. 125 N. 4 W. W.M.  
Bearing and distance from section or subdivision corner \_\_\_\_\_

(11) WATER LEVEL: Completed well.

Depth at which water was first found 140 ft.  
Static level 40 ft. below land surface. Date 11/17/77  
Artesian pressure \_\_\_\_\_ lbs. per square inch. Date \_\_\_\_\_

(12) WELL LOG:

Diameter of well below casing 6  
Depth drilled 140 ft. Depth of completed well 240 ft.  
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
<u>Top Soil &amp; Colours</u>	<u>0</u>	<u>4</u>	
<u>yellow clay</u>	<u>4</u>	<u>30</u>	
<u>Brown weathered shale</u>	<u>30</u>	<u>58</u>	
<u>Blue sandstone</u>	<u>58</u>	<u>140</u>	<u>40</u>
<u>Blue rock</u>	<u>140</u>	<u>240</u>	<u>40</u>

Work started 11/15 1977 Completed 11/17 1977  
Date well drilling machine moved off of well 11/17 1977

Drilling Machine Operator's Certification:  
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.  
[Signed] Frank Wilson Date 11/22, 1977  
(Drilling Machine Operator)  
Drilling Machine Operator's License No. 404

Water Well Contractor's Certification:  
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  
Name Ground Water System  
(Person, firm or corporation) (Type or print)  
Address 2320 Main st, Spfd, Oregon  
[Signed] Frank Wilson  
(Water Well Contractor)  
Contractor's License No. 562 Date Nov. 28, 1977

(USE ADDITIONAL SHEETS IF NECESSARY)

SP-0054-110







STATE OF OREGON  
WATER WELL REPORT  
(as required by ORS 537.765)

LANE  
2927

RECEIVED

JUN - 5 1992

(START CARD) #

18s/4w/10cc  
40517

(1) OWNER:  
Name Marion Parker Well Number \_\_\_\_\_  
Address 8666 S Bailey Hill Rd SALEM, OREGON 97302  
City Eugene State OR Zip 97405

(9) LOCATION OF WELL by legal description:  
Township 18 N of S Range 04 E of W/W.M.  
Section 10 SW M SW M  
Tax Lot \_\_\_\_\_ Lot \_\_\_\_\_ Block \_\_\_\_\_ Subdivision \_\_\_\_\_  
Street Address of Well (or nearest address) Same

(2) TYPE OF WORK:  
 New Well  Deepen  Recondition  Abandon

(3) DRILL METHOD  
 Rotary Air  Rotary Mud  Cable  
 Other

(4) PROPOSED USE:  
 Domestic  Community  Industrial  Irrigation  
 Thermal  Injection  Other

(5) BORE HOLE CONSTRUCTION:  
Special Construction approval Yes  No  Depth of Completed Well 160 ft.  
Explosives used  Yes  No  Type \_\_\_\_\_ Amount \_\_\_\_\_

HOLE			SEAL			Amount sacks or pounds
Diameter	From	To	Material	From	To	
10"	0	20	Cement	20	0	7 sacks
6"	20	160				

How was seal placed: Method  A  B  C  D  E  
 Other \_\_\_\_\_  
Backfill placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Material \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Size of gravel \_\_\_\_\_

(6) CASING/LINER:

Casing/Liner	Diameter	From	To	Gauge	Material			
					Steel	Plastic	Welded	Threaded
Casing	6"	72	20	250	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Liner					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Final location of shoe(s) \_\_\_\_\_  
(7) PERFORATIONS/SCREENS:  
 Perforations Method NA  
 Screens Type \_\_\_\_\_ Material \_\_\_\_\_

From	To	Slot size	Number	Diameter	Tele/pipe size	Casing	Liner
						<input type="checkbox"/>	<input type="checkbox"/>
						<input type="checkbox"/>	<input type="checkbox"/>
						<input type="checkbox"/>	<input type="checkbox"/>
						<input type="checkbox"/>	<input type="checkbox"/>

(8) WELL TESTS: Minimum testing time is 1 hour  
 Pump  Baller  Air  Flowing Artesian  
Yield gal/min 12 Drawdown 160 Drill stem at \_\_\_\_\_ Time \_\_\_\_\_  
Temperature of water 56° Depth Artesian Flow Found \_\_\_\_\_  
Was a water analysis done?  Yes By whom \_\_\_\_\_  
Did any strata contain water not suitable for intended use?  Too little  
 Salty  Muddy  Odor  Colored  Other \_\_\_\_\_  
Depth of strata: \_\_\_\_\_

(10) STATIC WATER LEVEL:  
45 ft. below land surface. Date 6-1-92  
Artesian pressure \_\_\_\_\_ lb. per square inch. Date \_\_\_\_\_

(11) WATER BEARING ZONES:  
Depth at which water was first found 90

From	To	Estimated Flow Rate	SWL
90	105	3	95
148	160	9	45

(12) WELL LOG: Ground elevation \_\_\_\_\_

Material	From	To	SWL
Brown Clay	0	3	
Lt Brown Clay	3	11	
Red Clay	11	18	
Yellow Clay	18	30	
Blue Clay	30	50	
Gray Clay	50	80	
Blue Clay	80	105	
Gray Clay	105	135	
Red Clay	135	148	
Blue Clay	148	160	

Date started 5-28-92 Completed 6-1-92

(unbonded) Water Well Constructor Certification:  
I certify that the work I performed on the construction, alteration, or abandonment of this well is in compliance with Oregon well construction standards. Materials used and information reported above are true to my best knowledge and belief.  
Signed \_\_\_\_\_ WWC Number \_\_\_\_\_  
Date \_\_\_\_\_

(bonded) Water Well Constructor Certification:  
I accept responsibility for the construction, alteration, or abandonment work performed on this well during the construction dates reported above. All work performed during this time is in compliance with Oregon well construction standards. This report is true to the best of my knowledge and belief.  
Signed Harold White WWC Number \_\_\_\_\_  
Date \_\_\_\_\_





RECEIVED

LANE  
1036

185/4w/146c

STATE OF OREGON  
WATER WELL REPORT  
(as required by ORS 537.760)

AUG 23 1993

WATER RESOURCES DEPARTMENT (START CARD) # W57464

(1) OWNER:  
Name Boward McBeth Well Number \_\_\_\_\_  
Address 86339 Lorane Bwy  
City Eugene State OR Zip 97405

(2) TYPE OF WORK:  
 New Well  Deepen  Recondition  Abandon

(3) DRILL METHOD:  
 Rotary Air  Rotary Mud  Cable  
 Other \_\_\_\_\_

(4) PROPOSED USE:  
 Domestic  Community  Industrial  Irrigation  
 Thermal  Injection  Other \_\_\_\_\_

(5) BORE HOLE CONSTRUCTION:  
Special Construction approval  Yes  No Depth of Completed Well 110 ft.  
Explosives used  Yes  No Type \_\_\_\_\_ Amount \_\_\_\_\_

HOLE		SEAL		Amount	
Diameter	From To	Material	From To	sacks or pounds	
10"	0 19'	Cement	0 19'	6 sacks	
6"	19' 110'				

How was seal placed: Method  A  B  C  D  E  
 Other \_\_\_\_\_

Backfill placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Material \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Size of gravel \_\_\_\_\_

(6) CASING/LINER:

Diameter	From	To	Gauge	Steel	Plastic	Welded	Threaded
Casing: 6"	+1'	19'	.250	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Liner:				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Final location of shoe(s) \_\_\_\_\_  
(7) PERFORATIONS/SCREENS:  
 Perforations Method \_\_\_\_\_  
 Screens Type \_\_\_\_\_ Material \_\_\_\_\_

From	To	Slot size	Number	Diameter	Tele/pipe size	Casing	Liner
						<input type="checkbox"/>	<input type="checkbox"/>
						<input type="checkbox"/>	<input type="checkbox"/>
						<input type="checkbox"/>	<input type="checkbox"/>
						<input type="checkbox"/>	<input type="checkbox"/>

(8) WELL TESTS: Minimum testing time is 1 hour  
 Pump  Bailor  Air  Flowing Artesian

Yield gal/min	Drawdown	Drill stem at	Time
12 1/2'	94'	110'	1 hr.
could fluctuate			

Temperature of Water 56° Depth Artesian Flow Found \_\_\_\_\_  
Was a water analysis done?  Yes  No By whom not tested  
Did any strata contain water not suitable for intended use?  Too little  
 Salty  Muddy  Odor  Colored  Other \_\_\_\_\_  
Depth of strata: \_\_\_\_\_

(9) LOCATION OF WELL by legal description:  
County Lane Latitude \_\_\_\_\_ Longitude \_\_\_\_\_  
Township 18S N or S, Range 4W E or W, WM.  
Section 14 SW 1/4 NW 1/4  
Tax Lot 2902 Lot \_\_\_\_\_ Block \_\_\_\_\_ Subdivision \_\_\_\_\_  
Street Address of Well (or nearest address) 86339 Lorane Bwy  
Eugene, OR

(10) STATIC WATER LEVEL:  
16 ft. below land surface. Date 7-19-93  
Artesian pressure \_\_\_\_\_ lb. per square inch. Date \_\_\_\_\_

(11) WATER BEARING ZONES:  
Depth at which water was first found 44'

From	To	Estimated Flow Rate	SWL
44'	45'	3 gpm	16'
76'	78'	9 1/2 gpm	16'

(12) WELL LOG: Ground elevation \_\_\_\_\_

Material	From	To	SWL
Topsoil	0	2'	
Brown clay	2'	11'	
Brown sandstone	11'	39'	
Blue, gray, white sandstone	39'	48'	16'
Brown sandstone	48'	57'	
Blue, gray sandstone	57'	71'	
Black basalt	71'	88'	16'
Gray sandstone	88'	108'	
Red claystone	108'	110'	

Date started 7-19-93 Completed 7-19-93

(unbonded) Water Well Constructor Certification:  
I certify that the work I performed on the construction, alteration, or abandonment of this well is in compliance with Oregon well construction standards. Materials used and information reported above are true to my best knowledge and belief.  
Signed Carey J. Jones Jr. WWC Number 1541  
Date 7-19-93

(bonded) Water Well Constructor Certification:  
I accept responsibility for the construction, alteration, or abandonment work performed on this well during the construction dates reported above. All work performed during this time is in compliance with Oregon well construction standards. This report is true to the best of my knowledge and belief.  
Signed Carey J. Jones Jr. WWC Number 1541  
Date 7-19-93

STATE OF OREGON  
 WATER WELL REPORT WATER RESOURCES DEPT.  
 (as required by ORS 537.765) SALEM, OREGON

JAN 31 1994

LANE 4472 18S/4W/14E  
 (START CARD) # W38168

(1) OWNER: Well Number #1  
 Name Barry Brown  
 Address 1100 S. 26th St.  
 City Springfield, State OR Zip 97477

(2) TYPE OF WORK:  
 New Well  Deepen  Recondition  Abandon

(3) DRILL METHOD:  
 Rotary Air  Rotary Mud  Cable  
 Other

(4) PROPOSED USE:  
 Domestic  Community  Industrial  Irrigation  
 Thermal  Injection  Other

(5) BORE HOLE CONSTRUCTION:  
 Special Construction approval  Yes  No Depth of Completed Well 120 ft.  
 Explosives used  Yes  No Type Amount

Diameter	HOLE		Material	SEAL		Amount sacks or pounds
	From	To		From	To	
10"	0	19'	Cement	0	19'	9 sacks
6"	19'	120'				

How was seal placed: Method  A  B  C  D  E  
 Other

Backfill placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Material \_\_\_\_\_  
 Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Size of gravel \_\_\_\_\_

(6) CASING/LINER:

Diameter	From	To	Gauge	Steel	Plastic	Welded	Threaded
Casing: 6"	+1'	19'	.250	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Liner: 4 1/2"	0	120'	PVC	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

Final location of shoe(s) \_\_\_\_\_

(7) PERFORATIONS/SCREENS:  
 Perforations Method SAW  
 Screens Type Material

From	To	Slot size	Number	Diameter	Tele/pipe size	Casing	Liner
40'	120'	1/8x2	800	4 1/2"		<input type="checkbox"/>	<input checked="" type="checkbox"/>

(8) WELL TESTS: Minimum testing time is 1 hour  
 Pump  Bailor  Air  Flowing Artesian

Yield gal/min	Drawdown	Drill stem at	Time
100	105'	120'	1 hr.
Could fluctuate			

Temperature of Water 56 Depth Artesian Flow Found \_\_\_\_\_  
 Was a water analysis done?  Yes By whom not tested  
 Did any strata contain water not suitable for intended use?  Too little  
 Salty  Muddy  Odor  Colored  Other  
 Depth of strata: \_\_\_\_\_

(9) LOCATION OF WELL by legal description:  
 County Lane Latitude Longitude  
 Township 18S N or S Range 4W E or W, WM.  
 Section 14 NW 1/4 NW 1/4 NW 1/4  
 Tax Lot 3700 Lot Block Subdivision  
 Street Address of Well (or nearest address) 1/4 mi northeast of  
 Spencer Creek Grange Loran Hwy on left

(10) STATIC WATER LEVEL:  
 15' ft. below land surface. Date 1-7-94  
 Artesian pressure \_\_\_\_\_ lb. per square inch. Date \_\_\_\_\_

(11) WATER BEARING ZONES:  
 Depth at which water was first found 73'

From	To	Estimated Flow Rate	SWL
73'	79'	5 gpm	15'
107'	108'	95 gpm	15'

(12) WELL LOG:  
 Ground elevation \_\_\_\_\_

Material	From	To	SWL
Topsoil	0	1'	
Clay & boulders	1'	11'	
Blue sandstone	11'	29'	
Red claystone	29'	32'	
Gray, green sandstone	32'	120'	15'

Date started 1-7-94 Completed 1-7-94

(unbonded) Water Well Constructor Certification:  
 I certify that the work I performed on the construction, alteration, or abandonment of this well is in compliance with Oregon well construction standards. Materials used and information reported above are true to my best knowledge and belief.  
 Signed John P. Jones WWC Number 1617  
 Date 1-7-94

(bonded) Water Well Constructor Certification:  
 I accept responsibility for the construction, alteration, or abandonment work performed on this well during the construction dates reported above. All work performed during this time is in compliance with Oregon well construction standards. This report is true to the best of my knowledge and belief.  
 Signed Casey Jones WWC Number 1541  
 Date 1-7-94

STATE OF OREGON  
WATER WELL REPORT  
(as required by ORS 537.769)

RECEIVED

JUN - 6 1994

WATER RESOURCES DEPT.

(START CARD) #

18s/4w/14ac  
54840

(1) OWNER: Well Number \_\_\_\_\_  
Name Larry Downaux  
Address 86319 Locane Hwy.  
City Engle State OR Zip 97402

(2) TYPE OF WORK:  
 New Well  Deepen  Recondition  Abandon

(3) DRILL METHOD:  
 Rotary Air  Rotary Mud  Cable  
 Other

(4) PROPOSED USE:  
 Domestic  Community  Industrial  Irrigation  
 Thermal  Infection  Other

(5) BORE HOLE CONSTRUCTION:  
Special Construction approval  Yes  No Depth of Completed Well 550 ft.  
Explosives used  Yes  No Type \_\_\_\_\_ Amount \_\_\_\_\_

HOLE		SEAL		Amount	
Diameter	From To	Material	From To	From To	sacks or pounds
10"	0 21	Bentonite	21 20	0	9 Sacks
6"	20 550				

How was seal placed: Method  A  B  C  D  E  
 Other Poured

Backfill placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Material \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Size of gravel \_\_\_\_\_

(6) CASING/LINER:

Diameter	From	To	Gauge	Steel	Plastic	Welded	Threaded
Casing: 6"	0	21	250	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Liner: 5"	0	539	199	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

Final location of shoe(s) \_\_\_\_\_  
(7) PERFORATIONS/SCREENS:  
 Perforations Method Factory  
 Screens Type \_\_\_\_\_ Material \_\_\_\_\_

From	To	Slot size	Number	Diameter	Telo/pipe size	Casing	Liner
459	519	1/2"	570	5"		<input type="checkbox"/>	<input checked="" type="checkbox"/>

(8) WELL TESTS: Minimum testing time is 1 hour  
 Pump  Bailor  Air  Flowing Artesian  
Yield gal/mhr \_\_\_\_\_ Drawdown \_\_\_\_\_ Drill stem at \_\_\_\_\_ Time \_\_\_\_\_  
15 \_\_\_\_\_ 550' \_\_\_\_\_ 1 hr.

Temperature of Water 54° Depth Artesian Flow Found \_\_\_\_\_  
Was a water analysis done?  Yes By whom \_\_\_\_\_  
Did any strata contain water not suitable for intended use?  Too little  
 Salty  Muddy  Odor  Colored  Other \_\_\_\_\_  
Depth of strata: \_\_\_\_\_

(9) LOCATION OF WELL by legal description:  
County Lane Latitude \_\_\_\_\_ Longitude \_\_\_\_\_  
Township 18 N or S Range 04 E or W  
Section 14 SW NE SE NW  
Tax Lot \_\_\_\_\_ Lot \_\_\_\_\_ Block \_\_\_\_\_ Subdivision \_\_\_\_\_  
Street Address of Well (or nearest address) End of Nealham Rd. off of Locane Hwy Engle OR 97402

(10) STATIC WATER LEVEL:  
190 ft. below land surface Date 5/24/94  
Artesian pressure \_\_\_\_\_ lb. per square inch. Date \_\_\_\_\_

(11) WATER BEARING ZONES:  
Depth at which water was first found 470'

From	To	Estimated Flow Rate	SWL
470	500	15 GPM	190

(12) WELL LOG: \_\_\_\_\_ Ground elevation \_\_\_\_\_

Material	From	To	SWL
Brown Topsoil	0	1	
tan clay	1	14	
Black Basalt	14	65	
gray Basalt	65	125	
Black Basalt	125	214	
Chert Limestone	214	240	
gray Limestone	240	270	
Red Limestone	270	280	
gray Limestone	280	390	
Blue Sandstone	390	410	
Gray Limestone	410	470	
Blue Sandstone	470	650	190

Date started 5/9/94 Completed 5/24/94  
(unbonded) Water Well Constructor Certification:

I certify that the work I performed on the construction, alteration, or abandonment of this well is in compliance with Oregon well construction standards. Materials used and information reported above are true to my best knowledge and belief.

Signed \_\_\_\_\_ WWC Number \_\_\_\_\_  
Date \_\_\_\_\_

(bonded) Water Well Constructor Certification:

I accept responsibility for the construction, alteration, or abandonment work performed on this well during the construction dates reported above. All work performed during this time is in compliance with Oregon well construction standards. This report is true to the best of my knowledge and belief.

Signed Sean O'Neil WWC Number 1562  
Date 5/27/94

STATE OF OREGON  
WATER WELL REPORT  
(as required by ORS 537.765)

RECEIVED

JUL 15 1994

WATER RESOURCES DEPT.

(START CARD) # W68222

Instructions for completing this report are on the last page of this form. SALEM, OREGON

(1) OWNER: Well Number \_\_\_\_\_  
Name Jay Chappell  
Address 86270 Lorane Hwy  
City Eugene State OR Zip 97405

(2) TYPE OF WORK  
 New Well  Deepening  Alteration (repair/recondition)  Abandonment

(3) DRILL METHOD:  
 Rotary Air  Rotary Mud  Cable  Auger  
 Other \_\_\_\_\_

(4) PROPOSED USE:  
 Domestic  Community  Industrial  Irrigation  
 Thermal  Injection  Livestock  Other \_\_\_\_\_

(5) BORE HOLE CONSTRUCTION:  
Special Construction approval  Yes  No Depth of Completed Well 330 ft.  
Explosives used  Yes  No Type \_\_\_\_\_ Amount \_\_\_\_\_

HOLE		SEAL		Material		Sacks or pounds	
Diameter	From To	From	To	From	To	From	To
10"	0	38'	0	38'	23	sacks	
6"	38'	330'					

How was seal placed: Method  A  B  C  D  E  
 Other \_\_\_\_\_

Backfill placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Material \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Size of gravel \_\_\_\_\_

(6) CASING/LINER:

Diameter	From	To	Gauge	Steel	Plastic	Welded	Threaded
Casing: 6"	+2'	38'	.250	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Liner: 4 1/2"	0	330'		<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

Final location of shoe(s) 30'

(7) PERFORATIONS/SCREENS:

From	To	Slot size	Number	Diameter	Telephone size	Casing	Liner
250'	270'	1/8x2	200	4 1/2"	PVC	<input type="checkbox"/>	<input checked="" type="checkbox"/>
310'	330'	1/8x2	400	4 1/2"	PVC	<input type="checkbox"/>	<input checked="" type="checkbox"/>

(8) WELL TESTS: Minimum testing time is 1 hour

Yield gal/min	Drawdown	Drill stem at	Flowing Artesian	Time
4	306'	330'	<input checked="" type="checkbox"/>	1 hr.
Could fluctuate				

Temperature of water 57 Depth Artesian Flow Found \_\_\_\_\_  
Was a water analysis done?  Yes By whom \_\_\_\_\_  
Did any strata contain water not suitable for intended use?  Top little  
 Salty  Muddy  Odor  Colored  Other \_\_\_\_\_  
Depth of strata: \_\_\_\_\_

(9) LOCATION OF WELL by legal description:  
County Lane Latitude \_\_\_\_\_ Longitude \_\_\_\_\_  
Township 18S N or S Range 4W E or W. WM. \_\_\_\_\_  
Section 15 NE 1/4 NE 1/4  
Tax Lot 100 Lot \_\_\_\_\_ Block \_\_\_\_\_ Subdivision \_\_\_\_\_  
Street Address of Well (or nearest address) 86270 Lorane Hwy  
Eugene, OR 97405

(10) STATIC WATER LEVEL:  
24 ft. below land surface. Date 7-8-94  
Artesian pressure \_\_\_\_\_ lb. per square inch. Date \_\_\_\_\_

(11) WATER BEARING ZONES:  
Depth at which water was first found 81'

From	To	Estimated Flow Rate	SWL
81'	82'	2 gpm	24'
277'	278'	2'	24'

(12) WELL LOG:  
Ground Elevation \_\_\_\_\_

Material	From	To	SWL
Topsail	0	2'	
Brown clay	2'	11'	
Blue basalt	11'	63'	
Blue, gray, conglomerate	63'	121'	24'
Blue basalt	121'	159'	
Blue, gray conglomerate	159'	205'	
Basalt	205'	250'	
Blue gray conglomerate	250'	330'	

Date started 7-4-94 Completed 7-8-94

(unbonded) Water Well Constructor Certification:  
I certify that the work I performed on the construction, alteration, or abandonment of this well is in compliance with Oregon water supply well construction standards. Materials used and information reported above are true to the best of my knowledge and belief.

Signed Casey L Jones WWC Number 1541 Date 7-8-94

(bonded) Water Well Constructor Certification:  
I accept responsibility for the construction, alteration, or abandonment work performed on this well during the construction dates reported above. All work performed during this time is in compliance with Oregon water supply well construction standards. This report is true to the best of my knowledge and belief.

Signed Casey L Jones WWC Number 329 Date \_\_\_\_\_

STATE OF OREGON  
WATER WELL REPORT  
(as required by ORS 537.765)

LANE  
50024

DEC 1 1995

(START CARD) # 58252

Instructions for completing this report are on the last page of this form.

(1) OWNER: Well Number 1  
Name Wayne Boden + Lenora Fisher  
Address 29800 Jarding Rd./P.O. Box 445  
City Fugate State OR Zip 97440

(2) TYPE OF WORK  
 New Well  Deepening  Alteration (repair/recondition)  Abandonment

(3) DRILL METHOD:  
 Rotary Air  Rotary Mud  Cable  Auger  
 Other

(4) PROPOSED USE:  
 Domestic  Community  Industrial  Irrigation  
 Thermal  Injection  Livestock  Other

(5) BORE HOLE CONSTRUCTION:  
Special Construction approval  Yes  No Depth of Completed Well 450 ft.  
Explosives used  Yes  No Type \_\_\_\_\_ Amount \_\_\_\_\_

HOLE			SEAL			Sacks or pounds
Diameter	From	To	Material	From	To	
10"	0	59'	Concrete w/ 4% bitcrete	0'	59'	15
6"	59'	450'				

How was seal placed: Method  A  B  C  D  E

Other \_\_\_\_\_

Backfill placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Material \_\_\_\_\_

Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Size of gravel \_\_\_\_\_

(6) CASING/LINER:

Diameter	From	To	Gauge	Steel	Plastic	Welded	Threaded
Casing: 6"	+1'	59'	250	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Liner: 4"	0	420'	160 BS	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

Final location of shoe(s) \_\_\_\_\_

(7) PERFORATIONS/SCREENS:

From	To	Shot size	Number	Diameter	Tele/pipe size	Casing	Liner
0	170		1	3/8	4	<input type="checkbox"/>	<input checked="" type="checkbox"/>
170	310		5	3/8	4	<input type="checkbox"/>	<input checked="" type="checkbox"/>
310	350		1	3/8	4	<input type="checkbox"/>	<input checked="" type="checkbox"/>
350	450		161	3/8	4	<input type="checkbox"/>	<input checked="" type="checkbox"/>

(8) WELL TESTS: Minimum testing time is 1 hour

Well output may fluctuate

Yield gal/min	Drawdown	Drill stem at	Flowing Time
50	273	450'	1 hr.

Temperature of water 51° Depth Artesian Flow Found \_\_\_\_\_

Was a water analysis done?  Yes By whom \_\_\_\_\_

Did any strata contain water not suitable for intended use?  Too little

Salty  Muddy  Odor  Colored  Other \_\_\_\_\_

Depth of strata: \_\_\_\_\_

(9) LOCATION OF WELL by legal description:  
County Lane Latitude \_\_\_\_\_ Longitude \_\_\_\_\_  
Township 18 S N or S Range 4 W E or W. WM.  
Section 15 SW 1/4 SE 1/4  
Tax Lot 900 Lot \_\_\_\_\_ Block \_\_\_\_\_ Subdivision \_\_\_\_\_  
Street Address of Well (or nearest address) 86081 Bailey Hill Dr Fugate, OR

(10) STATIC WATER LEVEL:  
177 ft. below land surface. Date 8/2/95  
Artesian pressure \_\_\_\_\_ lb. per square inch. Date \_\_\_\_\_

(11) WATER BEARING ZONES:  
Depth at which water was first found 185

From	To	Estimated Flow Rate	SWL
185	186	1/4	177
377	378	+ 4	177
402	403	+ 46	177

(12) WELL LOG:  
Ground Elevation \_\_\_\_\_

Material	From	To	SWL
Topsoil	0	3	
	3	27	
clay gray brown	27	47	
buff gray firm	47	57	
buff blue gray	57	118	
buff black hard	118	122	
buff black	122	130	
buff gray	130	161	
buff black hard	161	242	177
buff red	242	255	177
buff green-gray	255	330	177
buff red-gray	330	365	177
buff blue green	365	402	177
buff gray	402	450	177

Date started 7/28/95 Completed 8/2/95

(unbonded) Water Well Constructor Certification:  
I certify that the work I performed on the construction, alteration, or abandonment of this well is in compliance with Oregon water supply well construction standards. Materials used and information reported above are true to the best of my knowledge and belief.

WWC Number \_\_\_\_\_  
Signed \_\_\_\_\_ Date \_\_\_\_\_

(bonded) Water Well Constructor Certification:  
I accept responsibility for the construction, alteration, or abandonment work performed on this well during the construction dates reported above. All work performed during this time is in compliance with Oregon water supply well construction standards. This report is true to the best of my knowledge and belief.  
Signed Paul Christensen WWC Number 636 Date 8/16/95

RECEIVED

LANE 50594 APR 08 1996

STATE OF OREGON WATER SUPPLY WELL REPORT (as required by ORS 537.765)

WATER RESOURCES DEPT. WELLS DIVISION OREGON

(START CARD) # W91798

Instructions for completing this report are on the last page of this form.

(1) OWNER: Well Number #1 Name Breeden Bros. Address 366 East 40th City Eugene State OR Zip 97405

(2) TYPE OF WORK [X] New Well [ ] Deepening [ ] Alteration (repair/recondition) [ ] Abandonment

(3) DRILL METHOD: [X] Rotary Air [ ] Rotary Mud [ ] Cable [ ] Auger [ ] Other

(4) PROPOSED USE: [X] Domestic [ ] Community [ ] Industrial [ ] Irrigation [ ] Thermal [ ] Injection [ ] Livestock [ ] Other

(5) BORE HOLE CONSTRUCTION: Special Construction approval [ ] Yes [X] No Depth of Completed Well 380 ft. Explosives used [ ] Yes [X] No Type Amount

Table with columns: HOLE Diameter, SEAL Material, From, To, Sacks or pounds. Row 1: 10" 0 18' cement 0 18' 8 sacks. Row 2: 6" 18' 380'

How was seal placed: Method [ ] A [ ] B [X] C [ ] D [ ] E [ ] Other Backfill placed from ft. to ft. Material Gravel placed from ft. to ft. Size of gravel

(6) CASING/LINER: Table with columns: Diameter, From, To, Gauge, Steel, Plastic, Welded, Threaded. Casing: 6" +2' 18' 250' [X] [ ] [X] [ ]

(7) PERFORATIONS/SCREENS: Table with columns: From, To, Slot size, Number, Diameter, Material, Tele/pipe size, Casing, Liner.

(8) WELL TESTS: Minimum testing time is 1 hour [ ] Pump [ ] Bailer [X] Air [ ] Flowing Artesian Yield gal/min 2 1/2 Drawdown 375' Drill stem at 380' Time 1 hr.

Temperature of water 56 Depth Artesian Flow Found Was a water analysis done? [ ] Yes By whom Did any strata contain water not suitable for intended use? [ ] Too little [ ] Salty [ ] Muddy [ ] Odor [ ] Colored [ ] Other Depth of strata:

(9) LOCATION OF WELL by legal description: County Lane Latitude Longitude Township 18S N or S Range 4W E or W. WM. Section 11 SW 1/4 NW 1/4 Tax Lot 304 Lot Block Subdivision Street Address of Well (or nearest address) End of Timberline Dr., Eugene, OR

(10) STATIC WATER LEVEL: 58 ft. below land surface. Date Artesian pressure lb. per square inch. Date

(11) WATER BEARING ZONES: Depth at which water was first found 58'

Table with columns: From, To, Estimated Flow Rate, SWL. Row 1: 58' 59' 2 1/2 gpm 5'

(12) WELL LOG: Ground Elevation

Table with columns: Material, From, To, SWL. Rows include: Brown clay (0-3'), Brown broken up sandstone (3'-12'), Blue sandstone (12'-63'), Red claystone (63'-67'), Brown, green, blue sandstone (67'-123'), Gray, brown, white sandstone (123'-131'), Blue sandstone (131'-167'), Blue, green sandstone (167'-173'), Gray, tan sandstone (173'-193'), Red, green claystone (193'-221'), Green blue claystone (221'-263'), Red, blue, green claystone (263'-292'), Green blue claystone (292'-380')

Date started 3-7-96 Completed 3-8-96

(unbonded) Water Well Constructor Certification: I certify that the work I performed on the construction, alteration, or abandonment of this well is in compliance with Oregon water supply well construction standards. Materials used and information reported above are true to the best of my knowledge and belief. Signed [Signature] WWC Number 1617 Date 3-8-96

(bonded) Water Well Constructor Certification: I accept responsibility for the construction, alteration, or abandonment work performed on this well during the construction dates reported above. All work performed during this time is in compliance with Oregon water supply well construction standards. This report is true to the best of my knowledge and belief. Signed [Signature] WWC Number 1541 Date 3-8-96

STATE OF OREGON  
WATER SUPPLY WELL REPORT  
(as required by ORS 537.763)

LANE  
50595

(START CARD) # W91799

Instructions for completing this report are on the last page of this form.

(1) OWNER: Well Number 2  
Name Breeden Bros.  
Address 366 East 40th  
City Eugene State OR Zip 97405

(2) TYPE OF WORK  
 New Well  Deepening  Alteration (repair/recondition)  Abandonment

(3) DRILL METHOD:  
 Rotary Air  Rotary Mud  Cable  Auger  
 Other

(4) PROPOSED USE:  
 Domestic  Community  Industrial  Irrigation  
 Thermal  Injection  Livestock  Other

(5) HOLE HOLE CONSTRUCTION:  
Special Construction approval  Yes  No Depth of Completed Well 160 ft.  
Explosives used  Yes  No Type \_\_\_\_\_ Amount \_\_\_\_\_

HOLE			SEAL			
Diameter	From	To	Material	From	To	Sacks or pounds
10"	0	18'	Cement	0	18'	6 sacks
6"	18'	160'				

How was seal placed: Method  A  B  C  D  E  
 Other \_\_\_\_\_  
Backfill placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Material \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Size of gravel \_\_\_\_\_

(6) CASING/LINER:

Diameter	From	To	Gauge	Steel	Plastic	Welded	Threaded
Casing: 6"	+2'	18'	250	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Liner: 4 1/2"	0	160'	PVC	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

Final location of shoe(s) 18'

(7) PERFORATIONS/SCREENS:

Perforations Method SAW  
 Screens Type \_\_\_\_\_ Material \_\_\_\_\_

From	To	Slot size	Number	Diameter	Tele/pipe size	Casing	Liner
100'	160'	1/4x2	600	4 1/2"		<input type="checkbox"/>	<input checked="" type="checkbox"/>

(8) WELL TESTS: Minimum testing time is 1 hour

Yield gal/min	Drawdown	Drill stem at	Flowing Artesian
13	146'	160'	<input type="checkbox"/>

Temperature of water 55 Depth Artesian Flow Found \_\_\_\_\_

Was a water analysis done?  Yes By whom \_\_\_\_\_

Did any strata contain water not suitable for intended use?  Too little

Salty  Muddy  Odor  Colored  Other \_\_\_\_\_

Depth of strata: \_\_\_\_\_

(9) LOCATION OF WELL by legal description:  
County Lane Latitude \_\_\_\_\_ Longitude \_\_\_\_\_  
Township 18S N or S Range 4W E or W. WM.  
Section 11 SW 1/4 NW 1/4  
Tax Lot 303 Lot \_\_\_\_\_ Block \_\_\_\_\_ Subdivision \_\_\_\_\_  
Street Address of Well (or nearest address) Off end of Timberline Dr., Eugene, OR

(10) STATIC WATER LEVEL:  
14 ft. below land surface. Date 3-13-96  
Artesian pressure \_\_\_\_\_ lb. per square inch. Date \_\_\_\_\_

(11) WATER BEARING ZONES:  
Depth at which water was first found 68'

From	To	Estimated Flow Rate	SWL
68'	69'	4 gpm	14'
116'	117'	9 gpm	14'

(12) WELL LOG:  
Ground Elevation \_\_\_\_\_

Material	From	To	SWL
Brown clay	0	8'	
Brown, tan sandstone	8'	11'	
Blue, green sandstone	11'	38'	
Red claystone	38'	41'	
Blue, green sandstone	41'	123'	14'
Gray, green, sandstone	123'	134'	
Blue, green, brown, white sandst	134'	160'	

RECEIVED

APR 08 1996

WATER RESOURCES DEPT.  
SALEM, OREGON

Date started 3-13-96 Completed 3-13-96

(unbonded) Water Well Constructor Certification:

I certify that the work I performed on the construction, alteration, or abandonment of this well is in compliance with Oregon water supply well construction standards. Materials used and information reported above are true to the best of my knowledge and belief.

Signed John P. Platts WWC Number 1617  
Date 3-13-96

(bonded) Water Well Constructor Certification:

I accept responsibility for the construction, alteration, or abandonment work performed on this well during the construction dates reported above. All work performed during this time is in compliance with Oregon water supply well construction standards. This report is true to the best of my knowledge and belief.

Signed Carroll WWC Number 1541  
Date 3-13-96

STATE OF OREGON  
WATER SUPPLY WELL REPORT  
(as required by ORS 537.765)

LANE  
50600

(START CARD) # W91804

Instructions for completing this report are on the last page of this form.

(1) OWNER: Well Number 3  
Name Breeden Bros.  
Address 366 East 40th  
City Eugene State OR Zip 97405

(2) TYPE OF WORK  
 New Well  Deepening  Alteration (repair/recondition)  Abandonment

(3) DRILL METHOD:  
 Rotary Air  Rotary Mud  Cable  Auger  
 Other

(4) PROPOSED USE:  
 Domestic  Community  Industrial  Irrigation  
 Thermal  Injection  Livestock  Other

(5) BORE HOLE CONSTRUCTION:  
Special Construction approval  Yes  No Depth of Completed Well 220 ft.  
Explosives used  Yes  No Type \_\_\_\_\_ Amount \_\_\_\_\_

HOLE			SEAL			
Diameter	From	To	Material	From	To	Sacks or pounds
10"	0	58'	Cement	0	58'	18 sacks
6"	58'	220'				

How was seal placed: Method  A  B  C  D  E  
 Other

Backfill placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Material \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Size of gravel \_\_\_\_\_

(6) CASING/LINER:

Diameter	From	To	Gauge	Steel	Plastic	Welded	Threaded
Casing: 6"	+2'	58'	250	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Liner: 4 1/2"	0	220'		<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

Final location of shoe(s) 58'

(7) PERFORATIONS/SCREENS:

Perforations Method SAW  
 Screens Type \_\_\_\_\_ Material \_\_\_\_\_

From	To	Slot size	Number	Diameter	Tele./pipe size	Casing	Liner
140'	220'	1/8x2	600	4 1/2"		<input type="checkbox"/>	<input checked="" type="checkbox"/>

(8) WELL TESTS: Minimum testing time is 1 hour

Pump  Bailor  Air  Flowing  Artesian

Yield gal/min	Drawdown	Drill stem at	Time
21	145'	220'	1 hr.
Could fluctuate			

Temperature of water 56 Depth Artesian Flow Found \_\_\_\_\_

Was a water analysis done?  Yes By whom \_\_\_\_\_

Did any strata contain water not suitable for intended use?  Too little

Salty  Muddy  Odor  Colored  Other \_\_\_\_\_

Depth of strata: \_\_\_\_\_

(9) LOCATION OF WELL by legal description:  
County Lane Latitude \_\_\_\_\_ Longitude \_\_\_\_\_  
Township 18S N or S Range 4W E or W. WM.  
Section 11 SW 1/4 NW 1/4  
Tax Lot 304 Lot \_\_\_\_\_ Block \_\_\_\_\_ Subdivision \_\_\_\_\_  
Street Address of Well (or nearest address) Off end of Timberline Dr., Eugene, OR

(10) STATIC WATER LEVEL:  
75 ft. below land surface. Date 3-19-96  
Artesian pressure \_\_\_\_\_ lb. per square inch. Date \_\_\_\_\_

(11) WATER BEARING ZONES:  
Depth at which water was first found 113'

From	To	Estimated Flow Rate	SWL
113'	114'	4 gpm	75'
171'	172'	3 gpm	75'
202'	204'	14 gpm	75'

(12) WELL LOG:  
Ground Elevation \_\_\_\_\_

Material	From	To	SWL
Topsoil	0	1'	
Blue, brown, red sandstone	1'	9'	
Red claystone	9'	12'	
Gray, tan, brown sandstone	12'	51'	
Blue, green sandstone	51'	71'	
Green, red, white sandstone	71'	73'	
Blue, green sandstone	73'	165'	75'
Green, red sandstone	165'	168'	
Blue, green sandstone	168'	220'	75'

RECEIVED

APR 08 1996

WATER RESOURCES DEPT  
SALEM OREGON

Date started 3-18-96 Completed 3-19-96

(unbonded) Water Well Constructor Certification:  
I certify that the work I performed on the construction, alteration, or abandonment of this well is in compliance with Oregon water supply well construction standards. Materials used and information reported above are true to the best of my knowledge and belief.

Signed John P. [Signature] WWC Number 1617  
Date 3-19-96

(bonded) Water Well Constructor Certification:  
I accept responsibility for the construction, alteration, or abandonment work performed on this well during the construction dates reported above. All work performed during this time is in compliance with Oregon water supply well construction standards. This report is true to the best of my knowledge and belief.

Signed [Signature] WWC Number 1541  
Date 3-19-96



LANE 51061 RECEIVED  
JUL 25 1996

WELL ID = L02217

STATE OF OREGON  
WATER SUPPLY WELL REPORT  
(as required by ORS 537.763)

JUL 25 1996

(START CARD) # 90389

Instructions for completing this report are on the last page of this report.

(1) OWNER: Well Number 1401  
Name Neil Compton  
Address 973 Echo Hollow Rd  
City  Eugene  State  OR  Zip  97402

(2) TYPE OF WORK  
 New Well  Deepening  Alteration (repair/recondition)  Abandonment

(3) DRILL METHOD:  
 Rotary Air  Rotary Mud  Cable  Auger  
 Other

(4) PROPOSED USE:  
 Domestic  Community  Industrial  Irrigation  
 Thermal  Injection  Livestock  Other

(5) BORE HOLE CONSTRUCTION:  
Special Construction approval  Yes  No Depth of Completed Well 170'  
Explosives used  Yes  No Type \_\_\_\_\_ Amount \_\_\_\_\_

HOLE		SEAL	
Diameter	From To	Material	From To
10"	0' 29'	Bentonite	0' 29'
6"	29' 170'		9 Socks

How was seal placed: Method  A  B  C  D  E  
 Other Placed @ 1 sock per 5 min hole  
Backfill placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Material \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Size of gravel \_\_\_\_\_

(6) CASING/LINER:

Diameter	From	To	Gauge	Steel	Plastic	Welded	Threaded
Casing: 6"	0'	29'	280	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Liner: 4"	0'	170'	160	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

(7) PERFORATIONS/SCREENS:

Perforations Method Elect Saw  
 Screens Type \_\_\_\_\_ Material \_\_\_\_\_

From	To	Slot size	Number	Diameter	Tri/pipe size	Casing	Liner
30'	170'	3/16"	120			<input checked="" type="checkbox"/>	<input type="checkbox"/>

(8) WELL TESTS: Minimum testing time is 1 hour

Pump  Bailor  Air  Flowing  Artesian

Yield gal/min 5 GPM Drawdown \_\_\_\_\_ Drill stem at \_\_\_\_\_ Time \_\_\_\_\_ 1 hr.

Temperature of water 56° Depth Artesian Flow found \_\_\_\_\_  
Was a water analysis done?  Yes By whom \_\_\_\_\_  
Did any strata contain water not suitable for intended use?  Too little  
 Salty  Muddy  Odor  Colorist  Other \_\_\_\_\_  
Depth of strata: \_\_\_\_\_

(9) LOCATION OF WELL by legal description:  
County Lane Latitude \_\_\_\_\_ Longitude \_\_\_\_\_  
Township 18S N or S Range 04W E or W WM.  
Section 11 SE 1/4 SW 1/4  
Tax Lot 805 Lot \_\_\_\_\_ Block \_\_\_\_\_ Subdivision \_\_\_\_\_  
Street Address of Well (or nearest address) Lorraine Hwy

(10) STATIC WATER LEVEL:  
28' ft. below land surface. Date 6/20/96  
Artesian pressure \_\_\_\_\_ lb. per square inch. Date \_\_\_\_\_

(11) WATER BEARING ZONES:

Depth at which water was first found 74'

From	To	Estimated Flow Rate	SWL
74'	75'	5 GPM	28'

(12) WELL LOG:

Material	From	To	SWL
Topsoil	0	2	0
Blown clay	2	6	0
Weathered Sandstone	6	22	0
Grey Shale	22	36	0
Red Chert	36	41	0
Grey Shale	41	112	28'
Black Basalt	112	144	28'
Grey Shale	144	170	28'

Date started 6/20/96 Completed 6/20/96  
(unbonded) Water Well Constructor Certification:  
I certify that the work I performed on the construction, alteration, or abandonment of this well is in compliance with Oregon water supply well construction standards. Materials used and information reported above are true to the best of my knowledge and belief.  
Signed [Signature] WWC Number 1411  
Date \_\_\_\_\_

(bonded) Water Well Constructor Certification:  
I accept responsibility for the construction, alteration, or abandonment work performed on this well during the construction dates reported above. All work performed during this time is in compliance with Oregon water supply well construction standards. This report is true to the best of my knowledge and belief.  
Signed Donald Fleming WWC Number 751  
Date 6/20/96



lane  
52541

RECEIVED

JUL - 1 1997

Well ID# L14649

STATE OF OREGON  
WATER SUPPLY WELL REPORT WATER RESOURCES DEPT.  
(As required by ORS 537.765)  
SALEM, OREGON

(START CARD) # 94667

(1) OWNER: Well Number 1  
Name Laverne Cate  
Address 86340 Bailey Hill Rd.  
City Eugene State OR Zip 97405

(2) TYPE OF WORK  
 New Well  Deepening  Alteration (repair/recondition)  Abandonment

(3) DRILL METHOD:  
 Rotary Air  Rotary Mud  Cable  Auger  
 Other

(4) PROPOSED USE:  
 Domestic  Community  Industrial  Irrigation  
 Thermal  Injection  Livestock  Other

(5) BORE HOLE CONSTRUCTION:  
Special Construction approval  Yes  No Depth of Completed Well 235 ft.  
Explosives used  Yes  No Type \_\_\_\_\_ Amount \_\_\_\_\_

HOLE			SEAL			
Diameter	From	To	Material	From	To	Sacks or pounds
10"	0	48	cement	0	48	14 sacks
6"	48	235				

How was seal placed: Method  A  B  C  D  E  
 Other \_\_\_\_\_  
Backfill placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Material \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Size of gravel \_\_\_\_\_

(6) CASING/LINER:

Diameter	From	To	Gauge	Steel	Plastic	Welded	Threaded
Casing: 6"	+1	49	.250	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Liner: 4 1/2"	0	216	pvc	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

Final location of shoe(s) \_\_\_\_\_

(7) PERFORATIONS/SCREENS:

Perforations Method SAW  
 Screens Type \_\_\_\_\_ Material PVC

From	To	Slot size	Number	Diameter	Telephone size	Casing	Liner
156	216	1/8x2	600	4 1/2"		<input type="checkbox"/>	<input checked="" type="checkbox"/>

(8) WELL TESTS: Minimum testing time is 1 hour

<input type="checkbox"/> Pump	<input type="checkbox"/> Bailor	<input checked="" type="checkbox"/> Air	<input type="checkbox"/> Flowing Artesian
Yield gal/min	Drawdown	Drill stem at	Time
14.5	173	235	1 hr.

Temperature of water 61 Depth Artesian Flow Found \_\_\_\_\_  
Was a water analysis done?  Yes By whom \_\_\_\_\_  
Did any strata contain water not suitable for intended use?  Too little  
 Salty  Muddy  Odor  Colored  Other \_\_\_\_\_  
Depth of strata: \_\_\_\_\_

(9) LOCATION OF WELL by legal description:  
County Lane Latitude \_\_\_\_\_ Longitude \_\_\_\_\_  
Township 18S N or S Range 4W E or W. WM.  
Section 15 SW 1/4 SW 1/4  
Tax Lot 800 Lot \_\_\_\_\_ Block \_\_\_\_\_ Subdivision \_\_\_\_\_  
Street Address of Well (or nearest address) same

(10) STATIC WATER LEVEL:  
62 ft. below land surface. Date 6-18-97  
Artesian pressure \_\_\_\_\_ lb. per square inch. Date \_\_\_\_\_

(11) WATER BEARING ZONES:  
Depth at which water was first found 218

From	To	Estimated Flow Rate	SWL
218	225	14.5	62

(12) WELL LOG:  
Ground Elevation \_\_\_\_\_

Material	From	To	SWL
topsoil	0	1	
clay	1	40	
brown sandstone	40	56	
gray green brown sandstone	56	115	
brown claystone	115	125	
gray green brown sandstone	125	235	62

Date started 6-17-97 Completed 6-18-97

(unbonded) Water Well Constructor Certification:  
I certify that the work I performed on the construction, alteration, or abandonment of this well is in compliance with Oregon water supply well construction standards. Materials used and information reported above are true to the best of my knowledge and belief.  
Signed Mike D. WWC Number 1564 Date 6-19-97

(bonded) Water Well Constructor Certification:  
I accept responsibility for the construction, alteration, or abandonment work performed on this well during the construction dates reported above. All work performed during this time is in compliance with Oregon water supply well construction standards. This report is true to the best of my knowledge and belief.  
Signed [Signature] WWC Number 1541 Date 6-19-97



RECEIVED

STATE OF OREGON SEP 23 1997 #2 LANE 52917

WATER SUPPLY WELL REPORT (as required by ORS 216.010) WATER RESOURCES DEPT.

Instructions for completion are on the back page of this report.

WELL ID # W4789 (START CARD) # 102147

(1) OWNER: Name LEJAND INC, Address PO BOX 87, City DEXTER, State OR, Zip 97401

(2) TYPE OF WORK: [X] New Well [ ] Deepening [ ] Alteration (repair/recondition) [ ] Abandonment

(3) DRILL METHOD: [X] Rotary Air [ ] Rotary Mud [ ] Cable [ ] Auger [ ] Other

(4) PROPOSED USE: [X] Domestic [ ] Community [ ] Industrial [ ] Irrigation [ ] Thermal [ ] Injection [ ] Livestock [ ] Other

(5) BORE HOLE CONSTRUCTION: Special Construction approval [ ] Yes [X] No Depth of Completed Well 340 ft.

Table with columns for Diameter, From, To, Material, From, To, Sacks/Spools. Includes handwritten entries for 10 inch diameter and 6 inch seal.

How was seal placed: Method [ ] A [ ] B [X] C [ ] D [ ] E

Table for CASING/LINER with columns for Diameter, From, To, Gauge, Steel, Plastic, Welded, Threaded.

Final location of shoe(s)

(7) PERFORATIONS/SCREENS: Table with columns for From, To, Slot size, Number, Diameter, Material, Casing, Liner.

(8) WELL TESTS: Minimum testing time is 1 hour

Table for well tests with columns for Pump, Yield gal/min, Drawdown, Drill stem at, Flowing, Artesian, Time.

Temperature of water 58 Depth Artesian Flow Found Was a water analysis done? [ ] Yes [X] No

(9) LOCATION OF WELL by legal description: County LANE, Latitude 44°01.30'N, Longitude 123°09.52'W, Section 10, Tax Lot 101, Block 14, Subdivision 14, Street Address of Well 3250 Bailey Hill Rd, Eugene, OR

(10) STATIC WATER LEVEL: 205 ft. below land surface. Date 7/15/97

(11) WATER BEARING ZONES: Depth at which water was first found 280

Table for water bearing zones with columns for From, To, Estimated Flow Rate, SWL.

(12) WELL LOG: Ground Elevation

Table for well log with columns for Material, From, To, SWL. Includes handwritten entries for Top Soil, Mad Hard Brown, Sandstone, Lt Blue Mad Glass, Lt Blue White Crystalline.

Date started 7/15/97 Completed 7/15/97

(unbonded) Water Well Constructor Certification: I certify that the work I performed on the construction, alteration, or abandonment of this well is in compliance with Oregon water supply well construction standards.

WWC Number Signed Date

(bonded) Water Well Constructor Certification: I accept responsibility for the construction, alteration, or abandonment work performed on this well during the construction dates reported above.

WWC Number Signed Date

